


# REPAIRER'S DATA REPORT

**JOB NUMBER: 27861**



**Client: MINESPEC PARTS PTY LTD (QLD)**

**Description: REFURB EX5600 BOOM**

Document Name	Document ID	Version	Issue Date	Page
Workshop MDR	F_QA-013	1	10.02.2019	Page 1 of 9

## Technical Document Report Index

	Section	Records Provided	
		Yes	No
<b>Structural Integrity Survey Report pre-Overhaul</b>	<b>1</b>	✓	
<b>Certificate of Conformance</b>	<b>2</b>	✓	
<b>Client Purchase Orders</b>	<b>3</b>	✓	
<b>NDT Records</b>	<b>4</b>	✓	
<b>Welding Records / Procedures</b>	<b>5</b>	✓	
<b>Machining QA</b>	<b>6</b>	✓	
<b>Material Certs</b>	<b>7</b>	✓	

Document Name	Document ID	Version	Issue Date	Page
Workshop MDR	F_QA-013	1	10.02.2019	Page 2 of 9

*Section 1*

# Structural Integrity Survey Report pre-Overhaul

Document Name	Document ID	Version	Issue Date	Page
Workshop MDR	F_QA-013	1	10.02.2019	Page 3 of 9

---

## STRUCTURAL INTEGRITY SURVEY REPORT FOR THE STRUCTURE REPORT NUMBER HMI 23-033.7

---

# EXCAVATOR

INSPECTION CARRIED OUT FOR MACMAHON AT THE TROPICANA MINE SITE

**Inspection By:** G. Bailey (Heavy Machinery Inspections)  
**Inspection Period:** 16 to 23 April 2023  
**Report Date:** 23 April 2023  
**Site Contact:** Ms. T Cunningham  
**Order Number:** 4500179047  
**Order Number:** 4270970

### MACHINE DATA

**Fleet Number:** EX7115  
**Manufacturer:** Hitachi  
**Machine Model:** EX5600  
**Serial Number:** HCMKCA90J00002085  
**Boom Number:** 50  
**Arm Number:** 49  
**Hours:** 24155  
**Hours Since Last  
Inspection:** 3016

### INSPECTION OBJECTIVE

This inspection was performed to identify the presence of any internal and surface cracking in the structure.

The results and recommendations presented are to inform the owner of cracking and discontinuities that can be monitored and repaired in accordance with the categorization of the individual identified indications.

### INSPECTION SUMMARY

The inspection of the Hitachi EX5600 machine resulted in the detection seven (7) internal cracks and seven (7) visual cracks or crack groups.

## RESULTS

### Boom

The survey identified four internal cracks by the ultrasonic method. Refer Results Table and Diagrams 1 and 2.

The survey identified six visual cracks by the visual and magnetic particle examination methods. Refer Diagrams 1, 2 and 3 and Images 1, 2, 3, 4, 5, 6 and 7.

### Stick

The survey identified three internal cracks by the ultrasonic method. Refer Results Table and Diagrams 4, 5 and 6.

The survey identified nil visual cracking by the visual examination method.

### RESULTS TABLE

BOOM ULTRASONIC EXAMINATION		
Crack	Details	Cat.
U1	60mm long starting at 415mm up from the underside- right side	1
U2	75mm long starting at 240mm up from the underside- right side	1
U3	450mm long starting at 350mm up from underside- right side	1
U4	1040mm long starting at 395mm up from underside- left side (refer V3)	3
BOOM VISUAL EXAMINATION		
Crack	Details	Cat.
V1	180mm long at forward side of lift mount pin boss- right side	1
V2	65mm long at lower corner weld- left side	1
V3	165mm long behind grease lines associated with U4- left side	3
V4	60mm long at rear of the access window weld- left side	1
V5	305mm long on left front extending down at front edge on left side- upper side	5
V6	230mm long on right front end- upper side	3
STICK ULTRASONIC EXAMINATION		
Crack	Details	Cat.
U5	60mm long starting at 400mm down from upper side- right side	1
U6	65mm long starting at 560mm up from underside surface- left side	1
U7	205mm long starting at 715mm in from right side- underside	1
STICK VISUAL EXAMINATION		
Crack	Details	Cat.
--	No cracking identified	0

## RESULTS (Continued)

### Track Frame

The survey identified nil visual cracking by the visual method.

### Main Frame

The survey identified one visual crack, V7, by the visual and magnetic particle examination method. Refer Diagram 7 and Image 8.

### Right Side Frame

The survey identified nil visual cracking by the visual method.

### Left Side Frame

The survey identified nil visual cracking by the visual method.

### Inner Left Dog Bone

The survey identified nil visual cracking by the visual method.

### Inner Right Dog Bone

The survey identified nil visual cracking by the visual method.

### Outer Left Dog Bone

The survey identified nil visual cracking by the visual method.

### Outer Right Side Frame

The survey identified nil visual cracking by the visual method.

### 'H' Link

The survey identified nil visual cracking by the visual method.

## RECOMMENDATIONS

### Boom

The internal/visual crack, U4/V3 should be monitored continuously. Category 3. Criticality is high due to the internal length.

The internal cracks (U1, U2, U3, U5, U6 and U7 should be monitored. Category 1.

Repair of these cracks is not a recommendation prior to propagation to the surface.

## RECOMMENDATIONS (Continued)

Cracks V5 and V6 were repaired as a result of this inspection.

Crack V5 was categorised as 5 due to the extent of cracking.

Crack V6 was categorised as 3 due to the extent of cracking.

Cracks V1, V2 and V4 could be repaired in the long term as they were considered as subcritical. Category 1.

### Stick

The internal cracks identified within the machine structure should be monitored. Category 1.

Repair of these cracks is not a recommendation prior to propagation to the surface.

### Main Frame

Crack V6 could be repaired in the long to medium term as it was considered as subcritical. Category 1.

### General

Continue to monitor the structure in accordance with Macmahon inspection regime and any Hitachi inspection criteria.

A handwritten signature in blue ink, appearing to read 'G Bailey', is located below the general recommendation text.

G Bailey  
NDT Technician  
AINDT N83-18 (UT)  
AINDT N83-19 (MT/PT)

## INSPECTION DATA

### Ultrasonic Examination (UT)


**Ultrasonic Test Unit:** GE USN60L  
**Ultrasonic Test Probes:** GE MWB 45° 4MHz, MWB 60° 4MHz  
**Couplant:** Cellulose paste  
**Scanning Sensitivity:** 4mm Ø 4mm deep FBH + 12dB  
**Evaluation Sensitivity:** 4mm Ø 4mm deep FBH  
**Test Range:** 0 – 100mm  
**Thickness Range:** 19mm to 50mm  
**Test Restrictions:** Nil

### Visual Examination (VT)

**Visual Aid:** 4 X magnifying glass  
**Illumination:** Ambient and incandescent light source  
**Surface Condition:** As painted  
**Inspection Standard:** In accordance with AS 3978-2003  
**Inspection Criteria:** To detect possible surface cracking  
**Vision Acuity Level:** General- aided as necessary  
**Recording Device:** Digital imaging camera  
**Manufacturer:** Olympus Imaging Corp.  
**Model Number:** IM005  
**Serial Number:** BHWA61930  
**Resolution:** 16 megapixel  
**Test Restrictions:** Nil


### Magnetic Particle Examination (MT) [As required]

**Test Unit Type:** Electro-Spect PM-5 permanent magnet yoke  
**Magnetic Ink:** Ardrex 800/3  
**Background:** Ardrex 8901W (White)  
**Surface Condition:** As cast, as welded (suitable)  
**Test Type:** Continuous longitudinal magnetic flow  
**Test Method:** In general accordance with AS 1171  
**Sensitivity:** 2 lines (minimum)-Castrol-Burmah flux indicator  
**Inspection Criteria:** To detect possible cracking and to quantify cracking identified by visual inspection  
**Test Restrictions:** Nil



### EXCAVATOR COMPONENT NOMENCLATURE

BOOM- RIGHT SIDE




**Diagram 1**  
Schematic indicating crack locations in the right side of the boom



**Image 1**


View of crack V1 in right side in the pin boss weld at lift cylinder mount

BOOM- LEFT SIDE




**Diagram 2**

Schematic indicating crack locations in the left side of the boom



**Image 2**  
View of crack V2 in left side at the lower edge weld




**Image 3**  
View of crack V3 in left side associated with the internal bulkhead at this location



**Image 4**

View of crack V4 in left side associated with the access window weld adjacent to the operators' cabin


**BOOM- UPPER SIDE**




**Diagram 3**  
Schematic indicating crack locations in the upper side of the boom



**Image 5**  
View of crack V5 in upper left side at the front of the boom




**Image 6**  
View of the extension of crack V5 in upper left side at the front of the boom




**Image 7**  
View of crack V6 in upper right side at the front of the boom

STICK- RIGHT SIDE




**Diagram 4**  
Schematic indicating crack location in the right side of the stick

STICK- LEFT SIDE




**Diagram 5**  
Schematic indicating crack location in the left side of the stick

UNDERSIDE OF THE STICK



**Diagram 6**  
Schematic indicating crack location in the underside of the stick

TRACK FRAME- FORWARD SIDE



**Diagram 6**  
Schematic indicating crack location in the right side of the main



**Image 8**

View of crack V7 in right side at the main frame at the rear of the boom foot pin

**GENERAL GLOSSARY OF TERMS AND NOTATIONS- relating to all HMI reports (not including statutory inspections)**

**Ambient illumination**- background light without the use of additional lighting but generally, solar.

**Couplant/coupling medium**- a liquid or fluid compound, either oil, grease or cellulose past (wallpaper paste) applied to the component during ultrasonic testing to transfer ultrasonic waves into the test component from the test probe.

**DGS**- Distance Gain Size. A system by which a defects or discontinuities size can be determined by a comparison of reflectance to a known size reflector. In accordance with AS2207.

**FBH**- Flat-bottomed hole. This is used to set a level of sensitivity of an ultrasonic method as the most suitable in determining the presence of discontinuities or defects. The flat-bottomed hole is 4mm deep and 4mm in diameter. In accordance with Hitachi sizing method.

**Magnetic particle inspection (MT)**- a method of NDT used to detect surface breaking discontinuities or defects in carbon steels and cast irons utilising a 240V AC electromagnet yoke or permanent magnet yoke and magnetic inks to highlight those discontinuities or defects. In accordance with AS1171.

**NDT/Non Destructive Testing**- a series of methods of inspection and testing used to detect discontinuities or defects without the component under test being destroyed or damaged to locate and identify those discontinuities or defects.

**Paint stressing**- a condition noted in the surface paint of components where stresses have concentrated to form cracking in the paint, and where there has been either cracking or no cracking in the material of the component that the paint has been applied to.

**Thick Paint Syndrome (TPS)**

TPS is a condition in protective surface coatings that occurs when the coating is applied thickly and during the curing process the surface tension is high and tears initiate.

**Recommendations**- a series of actions that the inspector deems appropriate that the client may follow in relation to the severity of the discontinuities or defects identified in a test component.

**Categorization and severity levels of identified discontinuities or defects**- a set of criteria that the inspector deems that the identified discontinuities or defects in a component should be repaired. The criteria are based on a time frame that may be allowed to lapse before those discontinuities or defects pose a risk of failure or where further use of that component may become detrimental to the safety of personnel or production.

The categories and severities are as follows:

**Category 0**. a level of criticality where there were no identified discontinuities or defects or defective component. No further action required.

**Category 1. Subcritical**- a level of criticality where the identified discontinuities or defects or defective component should be removed or repaired in the long term. Generally, within 6 months or as monitoring of crack propagation dictates.

**Category 2. Hypocritical**- a level of criticality where the identified discontinuities or defects or defective component should be removed or repaired in the medium term. Generally, within 2-3 months or as monitoring of crack propagation dictates.

**Category 3. Critical**- a level of criticality where the identified discontinuities or defects or defective component should be removed or repaired in the short to medium term. Generally, within 1 month or as monitoring of crack propagation dictates.

**Category 4. Hypercritical**- a level of criticality where the identified discontinuities or defects or defective component should be removed or repaired in the short term. Generally, within 1-2 weeks or as monitoring of crack propagation dictates.

**Category 5. Supercritical**- a level of criticality where the identified discontinuities or defects or defective component should be removed or repaired in the short term. Generally, immediately or within 1 week or as monitoring of crack propagation dictates.

The time frames forwarded in the above criticalities are suggested only as extremes. The recommendations that could be suggested in the report recommendations may override these criticality time frames.

**Crack Group**- A crack group constitutes two or more cracks that could be adjacent to one another and not separated from each other by a distance greater than twice the length of the shortest crack or in line with each other and not separated from each other by a distance greater than the length of the longest crack, or a branched crack.

**SDH**- Side-drilled hole. This is used to set a level of sensitivity of an ultrasonic method as the most suitable in determining the presence of discontinuities or defects. The side-drilled hole is 1.5mm in diameter. In accordance with AS2207.

**U**- a notation used in a report defining an internal discontinuity or defect in a component detected by ultrasonic testing.

**Ultrasonic inspection (UT)**- a method of NDT used to detect surface breaking and internal discontinuities or defects in a material utilising high frequency sound waves to locate, identify and size those discontinuities or defects

**V**- a notation used in a report defining a surface breaking discontinuity or defect in a component detected by MT or visual inspection.

**Visual inspection (VI)**- a method of inspection using visual aids to identify surface discontinuities or defects. These visual aids include magnifying glasses, mirrors and appropriate light sources and digital cameras.

**Defect Location**- All reference is taken down from the upper surface of the component or up from the underside surface of the component or the left and right side edges of the component or up or down from a prominent adjacent weld.

Pointer location of internal cracking within diagrams is relative to the side of the of the internal bulkhead/stiffener plates i.e. the pointer ids directed to the rear of the internal bulkhead then the crack was identified on the rear side of the bulkhead.

**Schematics**- The schematics displayed in the reports are not to scale, are general in description and are to be used as a guide only.

**Disclaimer**

This inspection report does not in any way claim that all cracking in this equipment has been identified and reported. Unidentified cracking may exist as a result of poor access, obscuring by other components or excessive surface contamination unless stated nil restrictions. The results are described at the time of testing.

This report does not relinquish the owner or operator of the equipment from their duties of inspection as per the manufacturers requirements and their quality management procedures.

*Section 2*

# CERTIFICATE OF CONFORMANCE

Document Name	Document ID	Version	Issue Date	Page
Workshop MDR	F_QA-013	1	10.02.2019	Page 4 of 9

## CERTIFICATE OF CONFORMANCE

<b>Company Name:</b>	CQ Field Mining Services			
<b>Street Address:</b>	40 Production Dr			
<b>City / Suburb:</b>	Paget	<b>State:</b>	QLD	<b>Postcode:</b> 4740
		<b>CQFMS Part No:</b>	N/A	
<b>CQFMS Job No.:</b>	27861			
<b>Drawing No.:</b>	N/A	<b>Revision No:</b>	NA	
<b>Date of Overhaul:</b>	Dec 2023 to Feb 2024	<b>Qty Shipped:</b>	1	
<b>Date Shipped:</b>	23 <sup>rd</sup> February 2024	<b>Serial No.</b>	N/A	
<b>Description:</b>	Overhaul EX5600 Boom			
<b>Specification/Special Processes:</b>	N/A			

This is to certify that the products and/or services contracted by the Purchase Order have been manufactured, processes, inspected and tested in accordance with all requirements of the purchase order and specified on referenced documents.

Inspection and test results signify that the items delivered are fully acceptable and in complete conformance to all purchase order requirements.

Data and records, not enclosed with this shipment, are maintained on file and are available upon request.

<b>Signature:</b>		<b>Date:</b>	07/03/2024
<b>Position:</b>	Workshop Manager		

Document Name	Document ID	Version	Issue Date	Page
Certificate of Conformance	F_QA-015	1	28.02.2020	Page 1 of 1

*Section 3*

# QC CHECKLIST

Document Name	Document ID	Version	Issue Date	Page
Workshop MDR	F_QA-013	1	10.02.2019	Page 5 of 9



### Quality Control Worksheet

REVISION: 1.0

CUSTOMER

Customer PO No:

Minespec

Customer Contact:

CQFMS Job No:

CQFMS Project Co-Ord:

27861

Job Description:

Relevant Drawing No's:

Delivery Date:

Refurbish Minespec Hitachi Boom BX 5600

Tick

**Office Use (To be completed prior to issuing to workshop)**

	YES	NO	Comment	Responsible Person	Sign	Date
1 All relevant information and specification received	<input checked="" type="checkbox"/>			Supervisor Name		Date
2 Material ordered	<input checked="" type="checkbox"/>			Supervisor Name		Date
3 Job briefing with workshop personnel	<input checked="" type="checkbox"/>			Supervisor Name		Date
4 Risk Assessment complete	<input checked="" type="checkbox"/>			Supervisor Name		Date

**Workshop Use (Workshop Co-ordinator and personnel to complete)**

1 Items received correct from suppliers	<input checked="" type="checkbox"/>			Name		Date
2 Items processed correct (eg rolling and pressing)	<input checked="" type="checkbox"/>			Name		Date
3 Marking of hole location and size checked prior to drilling	<input checked="" type="checkbox"/>			Name		Date
4 Tack items checked and tested for correct position	<input checked="" type="checkbox"/>			BIMAL BASIL		Date
5 Items braced for distortion prior to welding	<input checked="" type="checkbox"/>			BIMAL BASIL		Date
6 Welding information identified	<input checked="" type="checkbox"/>			BIMAL BASIL		Date
7 NDT Required	<input checked="" type="checkbox"/>			J. Bozicev Name		7/3/24
8 <b>HOLD POINT - Do not proceed until signed</b>						
9 OK to start welding	<input checked="" type="checkbox"/>			BIMAL BASIL		12/12/23
10 Welding complete, job dressed and free from spatter	<input checked="" type="checkbox"/>			BIMAL BASIL		10/2/24
11 All hole and item locations rechecked after welding	<input checked="" type="checkbox"/>			BIMAL BASIL		10/2/24
12 Checked for distortion and fit-up				Name		Date
13 <b>HOLD POINT - Do not proceed until signed</b>						
14 Machining required-	<input checked="" type="checkbox"/>			Supervisor Name		Date
15 a. Specifications determined and provided to contractor	<input checked="" type="checkbox"/>			Supervisor Name		Date
14 Internal Lining required-	<input checked="" type="checkbox"/>			Supervisor Name		Date
15 a. Specifications determined and provided to contractor	<input checked="" type="checkbox"/>			Supervisor Name		Date
16 Surface treatment required-	<input checked="" type="checkbox"/>			Supervisor Name		Date
17 a. Specifications determined and provided to contractor	<input checked="" type="checkbox"/>			Supervisor Name		Date
18 Thickness, colour, quality checked	<input checked="" type="checkbox"/>			Name		Date
19 <b>HOLD POINT - Do not proceed until signed</b>						
20 Photo's taken	<input checked="" type="checkbox"/>			BIMAL BASIL		Date
21 Job ready for dispatch	<input checked="" type="checkbox"/>			Name		Date
22 Job completed and checked to quality standard	<input checked="" type="checkbox"/>			BIMAL BASIL		Date
23 Job loaded secure, items marked and protected	<input checked="" type="checkbox"/>			Name		Date
24 <b>Approved for release to the client</b>	<input checked="" type="checkbox"/>					

*Section 4*

# NDT RECORDS

Document Name	Document ID	Version	Issue Date	Page
Workshop MDR	F_QA-013	1	10.02.2019	Page 6 of 9



## N.D.T. TEST REPORT

ZT:sk  
11DEC23

**REPORT No:** R23-3540

Page 1 of 39

**CLIENT:** CQ Field Mining Services  
40 Production Drive  
Paget, Qld 4740

**CLIENT CONTACT:** Mr. B. Sedcole

**ORDER No:** 55056

**JOB No:** 27861

**DRAWING No.:** Not Supplied

**ITEM:** #EX5600 Boom

**DESCRIPTION:** *Initial* NDT & Inspection of EX5600 Boom  
at CQ Field Mining Services Workshop, Mackay.

**TECHNICIAN/S:** Mr. Z. Tass / Mr. J. Bozier / Mr. Z. Peulen / Mr. J. Friese

**DATE OF TEST:** 30NOV23 / 05DEC23 / 06DEC23

**WORKSHEET REF. No.:** MPI 23 – 44407  
UT 23 – 10177

**INSPECTION DATA:**

PROCEDURE No.: TP-301 / TP-702

AUST. STANDARD: AS 1171-1998/ AS 2207-2007

SURFACE FINISH: As Welded / Machined

SURFACE PREPARATION: Wire Buffed / Mechanical Cleaned (Needle Gunned)

SURFACE COATINGS: Nil

SURFACE CONDITION:  < 6.3µm Ra,  < 3.2µm Ra

ACC/REJ LIMITS: Record & Report all Cracking / Discontinuities

MATERIAL SPECIFICATION: Carbon Steel – No Further Specifications

LIMITATION: 0°, 45°, 60°, 70° Scans  
Limited Scanning Positions  
No Drawing Supplied

**EQUIPMENT:**

Ultrasonic     Radiographic     Penetrant  
 MPI             Other – Visual

Parker B300S Contour Probe AMP-039  
Castrol Flux Indicator Strip  
USM 36 Flaw Detector AUT-042  
Krautkramer-MSEB 4E 0° Ultrasonic Transducer AUT-166  
SIUI AFP2-89-45L 45° Ultrasonic Transducer AUT-177  
SIUI AFP2-89-60L 60° Ultrasonic Transducer AUT-178  
SIUI AFP2-89-70L 70° Ultrasonic Transducer AUT-179  
SIUI AFP4-89-45L 45° Ultrasonic Transducer AUT-180  
SIUI AFP4-89-60L 60° Ultrasonic Transducer AUT-187  
SIUI AFP4-89-70L 70° Ultrasonic Transducer AUT-182  
Calibration Block No.1 IIW V1 AUT-020  
Calibration Block No.2 IOW AUT-021  
Metric Universal Calibration Block AUT-029  
Headlamp

MAGNETISATION: Continuous Method

DEMAGNETISATION: No

REF. SENSITIVITY: MPI – 3 Lines Castrol Flux Indicator

CONSUMABLES: Ardrex, Black Magnetic Ink 800/3, Batch # 4980857866  
Ardrex, White Contrast Paint 8901/W, Batch # 4980129572



**RESULTS OF EXAMINATION**

**INSPECTION OF EX5600 BOOM:**

**Initial Magnetic Particle Inspection:**

**Worksheet No. 23 – 44407**

<b>Identification</b>	<b>Result</b>
External Boom Job No. 27861 <i>100% Inspection of Prepared Welds</i> <i>100% Inspection of Bores</i>	➤ Cracking Evident - Refer to Figures 1 to 4 & Table 1.0 for Results
Internal Boom Bay #1 Job No. 27861 <i>100% Inspection of Prepared Welds</i>	➤ Cracking Evident - Refer to Figures 5 & Table 2.0 for Results
Internal Boom Bay #2 Job No. 27861 <i>100% Inspection of Prepared Welds</i>	➤ Cracking Evident - Refer to Figures 6 & Table 3.0 for Results
Internal Boom Bay #3 Job No. 27861 <i>100% Inspection of Prepared Welds</i>	➤ Cracking Evident - Refer to Figures 7 & Table 4.0 for Results
Internal Boom Bay #4 Job No. 27861 <i>100% Inspection of Prepared Welds</i>	➤ Cracking Evident - Refer to Figures 8 & Table 5.0 for Results
Internal Boom Bay #5 Job No. 27861 <i>100% Inspection of Prepared Welds</i>	➤ Cracking Evident - Refer to Figures 9 & Table 6.0 for Results
Internal Boom Bay #6 Job No. 27861 <i>100% Inspection of Prepared Welds</i>	➤ Cracking Evident - Refer to Figures 10 & Table 7.0 for Results
Internal Boom Bay #7 Job No. 27861 <i>100% Inspection of Prepared Welds</i>	➤ Cracking Evident - Refer to Figures 11 & Table 8.0 for Results
Internal Boom Bay #8 Job No. 27861 <i>100% Inspection of Prepared Welds</i>	➤ Cracking Evident - Refer to Figures 12 & Table 9.0 for Results

**Note 1: Lighting Conditions comply with the Requirements of AS 1171 Section 3.5.2 – 1998.**

**RESULTS OF EXAMINATION CONTINUED**

**INSPECTION OF EX5600 BOOM:**

**Ultrasonic Inspection:**

**Worksheet No. 23 – 10177**

<b>Identification</b>	<b>Result</b>
Left Hand Rear Pivot End to Boom Body Job No. 27861 <i>100% Inspection of Welds</i>	➤ Nil Recordable Discontinuities Evident
Right Hand Rear Pivot End to Boom Body Job No. 27861 <i>100% Inspection of Welds</i>	➤ Nil Recordable Discontinuities Evident
Left Hand Front Pivot End to Boom Body Job No. 27861 <i>100% Inspection of Welds</i>	➤ <b>Recordable Discontinuities Evident</b> - Refer to Figure 11 & Table 8.0 for Results
Right Hand Front Pivot End to Boom Body Job No. 27861 <i>100% Inspection of Welds</i>	➤ <b>Recordable Discontinuities Evident</b> - Refer to Figure 10 & Table 7.0 for Results
Bay #2 – Existing Man Hole Cover Job No. 27861 <i>100% Inspection of Welds</i>	➤ Nil Recordable Discontinuities Evident
Bay #3 – Existing Man Hole Cover Job No. 27861 <i>100% Inspection of Welds</i>	➤ Nil Recordable Discontinuities Evident
Bay #4 – Existing Man Hole Cover Job No. 27861 <i>100% Inspection of Welds</i>	➤ Nil Recordable Discontinuities Evident
Bay #5 – Existing Man Hole Cover Job No. 27861 <i>100% Inspection of Welds</i>	➤ Nil Recordable Discontinuities Evident

**Note 1: Lighting Conditions comply with the Requirements of AS 3978 Section 6.1 – 2003**

**SUMMARY OF EXAMINATION**

**INSPECTION OF EX5600 BOOM:**

**Magnetic Particle Inspection / Ultrasonic Inspection: Worksheet No. 23 – 44407 / 10177**

Identification	Total No. of Defects	Total Length of Defects	Interpretation
External Boom	30	4966mm	New Cracking Evident
Internal Boom Bay #1	4	3120mm	New Cracking Evident
Internal Boom Bay #2	9	8820mm	New Cracking Evident
Internal Boom Bay #3	10	11200mm	New Cracking Evident
Internal Boom Bay #4	11	13900mm	New Cracking Evident
Internal Boom Bay #5	13	14250mm	New Cracking Evident
Internal Boom Bay #6	12	1900mm	New Cracking Evident
Internal Boom Bay #7	9	4560mm	New Cracking Evident
Internal Boom Bay #8	4	2890mm	New Cracking Evident

*Note 1: Lighting Conditions comply with the Requirements of AS 1171 Section 3.5.2 1998*

*Note 2: Lighting Conditions comply with the Requirements of AS 3978 Section 6.1 – 2003*

**Technicians:**

**Zackary Tass**

**Joshua Bozier**

**Zachary Peulen**

**Jayden Friese**





**Z. Tass - Senior Technician**



Approved NDT / Hydro Test Signatory

AS 3998 / ISO 9712 Level 2

MT, PT, UT, RT, CR/DR

(AINDT Registration No.4796)

**RESULTS OF EXAMINATION CONTINUED****FIGURE 1 – EXTERNAL TOP SIDE:****FIGURE 2 – EXTERNAL LEFT HAND SIDE:**

**RESULTS OF EXAMINATION CONTINUED****FIGURE 3 – EXTERNAL RIGHT HAND SIDE:****FIGURE 4 – EXTERNAL UNDERSIDE:****RIGHT**

**RESULTS OF EXAMINATION CONTINUED**

**TABLE 1.0 – EXTERNAL BOOM DEFECTS:**

<b>Defect No.</b>	<b>Length in mm</b>	<b>Defect No.</b>	<b>Length in mm</b>
<b>No. 1</b>	270	<b>No. 16</b>	650
<b>No. 2</b>	130	<b>No. 17</b>	650
<b>No. 3</b>	80	<b>No. 18</b>	5
<b>No. 4</b>	450	<b>No. 19</b>	10
<b>No. 5</b>	10	<b>No. 20</b>	100
<b>No. 6</b>	10	<b>No. 21</b>	50
<b>No. 7</b>	50	<b>No. 22</b>	10
<b>No. 8</b>	10	<b>No. 23</b>	5
<b>No. 9</b>	20	<b>No. 24</b>	70
<b>No. 10</b>	5, 3	<b>No. 25</b>	70
<b>No. 11</b>	100	<b>No. 26</b>	130
<b>No. 12</b>	450	<b>No. 27</b>	10
<b>No. 13</b>	10, 5, 3	<b>No. 28</b>	100
<b>No. 14</b>	1100	<b>No. 29</b>	100
<b>No. 15</b>	250	<b>No. 30</b>	50

PHOTOGRAPH NO. 1 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #1



PHOTOGRAPH NO. 2 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #2



PHOTOGRAPH NO. 3 - EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #3



PHOTOGRAPH NO. 4 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #4



PHOTOGRAPH NO. 5 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #5



PHOTOGRAPH NO. 6 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #6



PHOTOGRAPH NO. 7 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #7




PHOTOGRAPH NO. 8 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #8



PHOTOGRAPH NO. 9 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #9



PHOTOGRAPH NO. 10 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #10




PHOTOGRAPH NO. 11 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #11



PHOTOGRAPH NO. 12 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #12



PHOTOGRAPH NO. 13 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #13



PHOTOGRAPH NO. 14 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #14



PHOTOGRAPH NO. 15 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #15



PHOTOGRAPH NO. 16 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #16



PHOTOGRAPH NO. 17 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #17



PHOTOGRAPH NO. 18 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #18



PHOTOGRAPH NO. 19 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #19



PHOTOGRAPH NO. 20 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #20



PHOTOGRAPH NO. 21 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #21



PHOTOGRAPH NO. 22 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #22



PHOTOGRAPH NO. 23 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #23



PHOTOGRAPH NO. 24 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #24



PHOTOGRAPH NO. 25 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #25



PHOTOGRAPH NO. 26 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #26



PHOTOGRAPH NO. 27 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #27




PHOTOGRAPH NO. 28 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #28



PHOTOGRAPH NO. 29 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #29




PHOTOGRAPH NO. 30 – EXTERNAL BOOM  
TYPICAL VIEW OF DEFECT #30



**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 5 – INTERNAL BAY #1:**



**TABLE 2.0 – INTERNAL BAY #1:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	360 BC	No. 3	10 SW
No. 2	1200 SW	No. 4	800, 750 TC

TC = Top Chord  
BC = Bottom Chord


FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole

PHOTOGRAPH NO. 31 – INTERNAL BOOM BAY #1  
TYPICAL VIEW OF DEFECT #1



PHOTOGRAPH NO. 32 – INTERNAL BOOM BAY #1  
TYPICAL VIEW OF DEFECT #2



PHOTOGRAPH NO. 33 – INTERNAL BOOM BAY #1  
TYPICAL VIEW OF DEFECT #3




PHOTOGRAPH NO. 34 – INTERNAL BOOM BAY #1  
TYPICAL VIEW OF DEFECT #4



**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 6 – INTERNAL BAY #2:**



**TABLE 3.0 – INTERNAL BAY #2 DEFECTS:**


Defect No.	Length in mm	Defect No.	Length in mm
No. 1	1300 SW	No. 6	40, 10 TC
No. 2	10 MH	No. 7	650 SW
No. 3	10 MH	No. 8	1700 TC
No. 4	1700 BC	No. 9	1700 BC
No. 5	1700 TC		

TC = Top Chord  
BC = Bottom Chord

FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole

PHOTOGRAPH NO. 35 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF DEFECT #1



PHOTOGRAPH NO. 36 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF DEFECT #2



PHOTOGRAPH NO. 37 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF DEFECT #3



PHOTOGRAPH NO. 38 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF DEFECT #4



PHOTOGRAPH NO. 39 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF DEFECT #5



PHOTOGRAPH NO. 40 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF DEFECT #6



PHOTOGRAPH NO. 41 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF DEFECT #7



PHOTOGRAPH NO. 42 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF DEFECT #8




PHOTOGRAPH NO. 43 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF DEFECT #9



INTENTIONALLY LEFT BLANK

## RESULTS OF EXAMINATION CONTINUED

**FIGURE 7 – INTERNAL BAY #3:**



**TABLE 4.0 – INTERNAL BAY #3 DEFECTS:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	500 SW	No. 6	1400 SW
No. 2	700 SW	No. 7	1500 TC
No. 3	1500 TC	No. 8	600 SW
No. 4	1400 SW	No. 9	600 SW
No. 5	1500 BC	No. 10	1500 BC

TC = Top Chord  
BC = Bottom Chord

FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole

PHOTOGRAPH NO. 44 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF DEFECT #1



PHOTOGRAPH NO. 45 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF DEFECT #2



PHOTOGRAPH NO. 46 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF DEFECT #3



PHOTOGRAPH NO. 47 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF DEFECT #4



PHOTOGRAPH NO. 48 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF DEFECT #5



PHOTOGRAPH NO. 49 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF DEFECT #6



PHOTOGRAPH NO. 50 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF DEFECT #7



PHOTOGRAPH NO. 51 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF DEFECT #8



PHOTOGRAPH NO. 52 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF DEFECT #9




PHOTOGRAPH NO. 53 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF DEFECT #10



**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 8 – INTERNAL BAY #4:**



**TABLE 5.0 – INTERNAL BAY #4 DEFECTS:**


Defect No.	Length in mm	Defect No.	Length in mm
No. 1	1800 SW	No. 7	1000 SW
No. 2	50 TC	No. 8	50 TC
No. 3	1400 TC	No. 9	600 BC
No. 4	1500 BC	No. 10	1800 SW
No. 5	2800 TC/SW	No. 11	100 MH
No. 6	2800 TC/SW		

TC = Top Chord  
BC = Bottom Chord

FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole

PHOTOGRAPH NO. 54 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #1



PHOTOGRAPH NO. 55 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #2



PHOTOGRAPH NO. 56 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #3



PHOTOGRAPH NO. 57 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #4



PHOTOGRAPH NO. 58 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #5



PHOTOGRAPH NO. 59 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #6



PHOTOGRAPH NO. 60 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #7



PHOTOGRAPH NO. 61 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #8



PHOTOGRAPH NO. 62 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #9



PHOTOGRAPH NO. 63 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #10




PHOTOGRAPH NO. 64 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF DEFECT #11



INTENTIONALLY LEFT BLANK

**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 9 – INTERNAL BAY #5:**



**TABLE 6.0 – INTERNAL BAY #5 DEFECTS:**


Defect No.	Length in mm	Defect No.	Length in mm
No. 1	600 TC	No. 8	2200 TT/SW
No. 2	400 SW	No. 9	3600 BC
No. 3	200 SW	No. 10	3600 BC
No. 4	150 SW	No. 11	1100 TC
No. 5	600 TC	No. 12	300 TC
No. 6	200 TT	No. 13	300 TC
No. 7	1000 TT/SW		

TC = Top Chord  
 BC = Bottom Chord  
 TT = Torque Tube

FW = Front Wall  
 RW = Rear Wall

SW = Side Wall  
 MH = Man Hole


PHOTOGRAPH NO. 65 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #1



PHOTOGRAPH NO. 66 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #2



PHOTOGRAPH NO. 67 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #3



PHOTOGRAPH NO. 68 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #4



PHOTOGRAPH NO. 69 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #5



PHOTOGRAPH NO. 70 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #6



PHOTOGRAPH NO. 71 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #7



PHOTOGRAPH NO. 72 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #8



PHOTOGRAPH NO. 73 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #9



PHOTOGRAPH NO. 74 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #10



PHOTOGRAPH NO. 75 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #11



PHOTOGRAPH NO. 76 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #12




PHOTOGRAPH NO. 77 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF DEFECT #13



INTENTIONALLY LEFT BLANK

**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 10 – INTERNAL BAY #6:**



**TABLE 7.0 – INTERNAL BAY #6 DEFECTS:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	370 BC	No. 7	360 TC
No. 2	130 MH	No. 8	80 TC
No. 3	140 SW	No. 9	60 TC
No. 4	90 SW	No. 10	120 MH
No. 5	220 MH	No. 11	170 TC
No. 6	30 SW	No. 12	70, 60 TC

TC = Top Chord  
BC = Bottom Chord

FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole

PHOTOGRAPH NO. 78 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #1



PHOTOGRAPH NO. 79 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #2



PHOTOGRAPH NO. 80 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #3



PHOTOGRAPH NO. 81 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #4



PHOTOGRAPH NO. 82 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #5



PHOTOGRAPH NO. 83 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #6



PHOTOGRAPH NO. 84 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #7



PHOTOGRAPH NO. 85 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #8



PHOTOGRAPH NO. 86 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #9



PHOTOGRAPH NO. 87 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #10



PHOTOGRAPH NO. 88 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #11




PHOTOGRAPH NO. 89 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF DEFECT #12



**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 11 – INTERNAL BAY #7:**



**TABLE 8.0 – INTERNAL BAY #7 DEFECTS:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	150 BC	No. 6	530 SW
No. 2	190 BC	No. 7	1200 SW
No. 3	1150 SW	No. 8	170 TC
No. 4	250 TC	No. 9	720 TC
No. 5	350 MH		

TC = Top Chord  
BC = Bottom Chord

FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole


PHOTOGRAPH NO. 90 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF DEFECT #1



PHOTOGRAPH NO. 91 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF DEFECT #2



PHOTOGRAPH NO. 92 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF DEFECT #3



PHOTOGRAPH NO. 93 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF DEFECT #4



PHOTOGRAPH NO. 94 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF DEFECT #5



PHOTOGRAPH NO. 95 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF DEFECT #6



PHOTOGRAPH NO. 96 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF DEFECT #7




PHOTOGRAPH NO. 97 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF DEFECT #8



PHOTOGRAPH NO. 98 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF DEFECT #9



INTENTIONALLY LEFT BLANK


**RESULTS OF EXAMINATION CONTINUED****FIGURE 12 – INTERNAL BAY #8:****TABLE 9.0 – INTERNAL BAY #8:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	350 BC	No. 3	40 TC
No. 2	650, 1100 SW	No. 4	750 TC

PHOTOGRAPH NO. 99 – INTERNAL BOOM BAY #8  
TYPICAL VIEW OF DEFECT #1




PHOTOGRAPH NO. 100 – INTERNAL BOOM BAY #8  
TYPICAL VIEW OF DEFECT #2



PHOTOGRAPH NO. 101 – INTERNAL BOOM BAY #8  
TYPICAL VIEW OF DEFECT #3




PHOTOGRAPH NO. 102 – INTERNAL BOOM BAY #8  
TYPICAL VIEW OF DEFECT #4



PHOTOGRAPH NO. 103 – GENERAL VIEW OF EX5600 BOOM



PHOTOGRAPH NO. 104 – GENERAL VIEW OF EX5600 BOOM



PHOTOGRAPH NO. 105 – GENERAL VIEW OF EX5600 BOOM



PHOTOGRAPH NO. 106 – GENERAL VIEW OF EX5600 BOOM





## N.D.T. TEST REPORT

ZT:sk  
08MAR24

**REPORT No.:** R23-3540a Page 1 of 41

**CLIENT:** CQ Field Mining Services  
40 Production Drive  
Paget, Qld 4740

**CLIENT CONTACT:** Mr. B. Sedcole

**ORDER No.:** 55056

**JOB No.:** 27861

**DRAWING No.:** Not Supplied

**ITEM:** #EX5600 Boom

**DESCRIPTION:** *Final* NDT & Inspection of EX5600 Boom  
at CQ Field Mining Services Workshop, Mackay.

**TECHNICIAN/S:** Mr. Z. Tass / Mr. J. Bozier / Mr. Z. Peulen /  
Mr. J. Friese / Mr. B. Bell

**DATE OF TEST:** 16JAN24 / 25JAN24 / 29JAN24 / 31JAN24 / 01FEB24 / 12FEB24

**WORKSHEET REF. No.:** MPI 24 – 45133  
VIS 24 – 9285  
UT 24 – 10413  
CON 24 – 3364

**INSPECTION DATA:**

PROCEDURE No.: TP-001 / TP-301 / TP-702

TEST STANDARD: AS 3978-2003 / AS 1171-1998 / AS 2207-2007

ASSOCIATED STANDARD: AS/NZS 1554.1-2014

SURFACE FINISH: As Welded

SURFACE PREPARATION: Blended

SURFACE COATINGS: Nil

SURFACE CONDITION:  < 6.3µm Ra,  < 3.2µm Ra

ACC/REJ LIMITS: AS/NZS 1554.1 2014 Cat SP Table 6.2.2  
AS/NZS 1554.1 2014 Table 6.2.1

MATERIAL SPECIFICATION: Carbon Steel – No Further Specifications

LIMITATION: 0°, 45°, 60°, 70° Scans

**EQUIPMENT:**

Ultrasonic     Radiographic     Penetrant  
 MPI             Other – Visual

Parker B300S Contour Probe AMP-047  
Castrol Flux Indicator Strip  
USM 36 Flaw Detector AUT-041  
Krautkramer-MSEB-4E 0° Ultrasonic Transducer AUT-139  
SIUI AFP2-89-45L 45° Ultrasonic Transducer AUT-171  
SIUI AFP2-89-60L 60° Ultrasonic Transducer AUT-172  
SIUI AFP2-89-70L 70° Ultrasonic Transducer AUT-173  
SIUI AFP4-89-45L 45° Ultrasonic Transducer AUT-174  
SIUI AFP4-89-60L 60° Ultrasonic Transducer AUT-175  
SIUI AFP4-89-70L 70° Ultrasonic Transducer AUT-176  
Calibration Block No.1 IIW V1 AUT-020  
Calibration Block No.2 IOW AUT-021  
Metric Universal Calibration Block AUT-029  
Headlamp

MAGNETISATION: Continuous Method

DEMAGNETISATION: No

REF. SENSITIVITY: MPI – 3 Lines Castrol Flux Indicator

CONSUMABLES: Ardrex, Black Magnetic Ink 800/3, Batch # 4980857866  
Ardrex, White Contrast Paint 8901/W, Batch # 4980129572

**INSPECTION DATA CONTINUED:**

TEMPERATURE:                     10° - 14°         15° - 45°         46° - 50°

RECORD:                            Photograph

LIGHTING:                        1200 Lux

% COMPLETION:                100%

ACCESS:                          100%

MAGNIFICATION:                Nil

**ULTRASONIC INSPECTION DATA:**

THICKNESS RANGE:              0 – 32mm / 0 – 50mm / 0 – 65mm

RANGE:                            0° Scan: 0 – 150mm  
45°, 60°, 70° Scans: 0 – 250mm / 0 – 400mm

REF SENSITIVITY:                2<sup>nd</sup> BWEFSH / 80% Reference

EVALUATION SENSITIVITY:      Level 2

SCAN POSITION:                  UMB

SURFACE CONDITION:          SP1

WELD PROCESS:                 Not Specified

SIZING:                          6dB / 20dB

TEST ACCURACY:                ± 0.5mm

COUPLANT:                        Kerosene

CURVATURE COMPENSATION:    Not Applicable

## RESULTS OF EXAMINATION

### INSPECTION OF EX5600 BOOM:

**Final Magnetic Particle Inspection:**
**Worksheet No. 24 - 45133**

Identification	Result
External Boom Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Cracking / Defects Evident - Refer to Figures 1 to 4 &amp; Table 1.0</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #1 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Cracking / Defects Evident - Refer to Figures 5 &amp; Table 2.0</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #2 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Cracking / Defects Evident - Refer to Figures 6 &amp; Table 3.0</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #3 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Cracking / Defects Evident - Refer to Figures 7 &amp; Table 4.0</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #4 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Cracking / Defects Evident - Refer to Figures 8 &amp; Table 5.0</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #5 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Cracking / Defects Evident - Refer to Figures 9 &amp; Table 6.0</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #6 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Cracking / Defects Evident - Refer to Figures 10 &amp; Table 7.0</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>

**Note 1: Lighting Conditions comply with the Requirements of AS 1171 Section 3.5.2 – 1998.**

### RESULTS OF EXAMINATION CONTINUED

#### INSPECTION OF EX5600 BOOM:

##### **Final Magnetic Particle Inspection:**

**Worksheet No. 24 - 45133**

Identification	Result
Internal Boom Bay #7 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Cracking / Defects Evident - Refer to Figures 11 &amp; Table 8.0</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #8 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Cracking / Defects Evident - Refer to Figures 12 &amp; Table 9.0</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
New Man Hole Covers (x8) Job No. 27861 <i>100% Inspection of Welds</i>	<ul style="list-style-type: none"> <li>➤ Nil Cracking / Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>

**Note 1: Lighting Conditions comply with the Requirements of AS 1171 Section 3.5.2 – 1998.**

##### **Visual Inspection:**

**Worksheet No. 24 - 9285**

Identification	Result
External Boom Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #1 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #2 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #3 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>

**Note: Lighting Conditions comply with the Requirements of AS 3978 Section 6.1 - 2003**

### RESULTS OF EXAMINATION CONTINUED

#### INSPECTION OF EX5600 BOOM:

**Visual Inspection:**
**Worksheet No. 24 - 9285**

Identification	Result
Internal Boom Bay #4 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #5 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #6 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #7 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
Internal Boom Bay #8 Job No. 27861 <i>100% Inspection of Weld Repairs</i>	<ul style="list-style-type: none"> <li>➤ Nil Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>
New Man Hole Covers (x8) Job No. 27861 <i>100% Inspection of Welds</i>	<ul style="list-style-type: none"> <li>➤ Nil Defects Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Cat SP Table 6.2.2</li> </ul>

**Note:** *Lighting Conditions comply with the Requirements of AS 3978 Section 6.1 - 2003*

**Ultrasonic Inspection:**
**Worksheet No. 24 - 10413**

Identification	Result
New Man Hole Covers (x8) Job No. 27861 <i>30% Inspection of Welds</i>	<ul style="list-style-type: none"> <li>➤ Nil Recordable Discontinuities Evident</li> <li>➤ Complies with the Requirements of AS/NZS 1554.1 2014 Table 6.2.1</li> </ul>

**Note 1:** *Lighting Conditions comply with the Requirements of AS 3978 Section 6.1 – 2003*

**SUMMARY OF EXAMINATION****INSPECTION OF EX5600 BOOM:****Magnetic Particle / Visual / Ultrasonic Inspection: Worksheet No. 24 – 45133 / 9285 / 10413**

<b>Identification</b>	<b>Total No. of Changes</b>	<b>Interpretation</b>
External Boom	30	Defects Repaired Since Last Inspection
Internal Boom Bay #1	4	Defects Repaired Since Last Inspection
Internal Boom Bay #2	9	Defects Repaired Since Last Inspection
Internal Boom Bay #3	10	Defects Repaired Since Last Inspection
Internal Boom Bay #4	11	Defects Repaired Since Last Inspection
Internal Boom Bay #5	13	Defects Repaired Since Last Inspection
Internal Boom Bay #6	12	Defects Repaired Since Last Inspection
Internal Boom Bay #7	9	Defects Repaired Since Last Inspection
Internal Boom Bay #8	4	Defects Repaired Since Last Inspection

*Note 1: Lighting Conditions comply with the Requirements of AS 1171 Section 3.5.2 1998**Note 2: Lighting Conditions comply with the Requirements of AS 3978 Section 6.1 – 2003***Technicians:****Zackary Tass****Joshua Bozier****Zachary Peulen****Jayden Friese****Brdoie Bell**



**Z. Tass - Senior Technician**

Approved NDT / Hydro Test Signatory

AS 3998 / ISO 9712 Level 2


MT, PT, UT, RT, CR/DR

(AINDT Registration No.4796)

**RESULTS OF EXAMINATION CONTINUED****FIGURE 1 – EXTERNAL TOP SIDE:****FIGURE 2 – EXTERNAL LEFT HAND SIDE:**


## RESULTS OF EXAMINATION CONTINUED

**FIGURE 3 – EXTERNAL RIGHT HAND SIDE:**



**FIGURE 4 – EXTERNAL UNDERSIDE:**

**RIGHT**



**RESULTS OF EXAMINATION CONTINUED**

**TABLE 1.0 – EXTERNAL BOOM REPAIRED DEFECTS:**

<b>Defect No.</b>	<b>Length in mm</b>	<b>Defect No.</b>	<b>Length in mm</b>
<b>No. 1</b>	270	<b>No. 16</b>	650
<b>No. 2</b>	130	<b>No. 17</b>	650
<b>No. 3</b>	80	<b>No. 18</b>	5
<b>No. 4</b>	450	<b>No. 19</b>	10
<b>No. 5</b>	10	<b>No. 20</b>	100
<b>No. 6</b>	10	<b>No. 21</b>	50
<b>No. 7</b>	50	<b>No. 22</b>	10
<b>No. 8</b>	10	<b>No. 23</b>	5
<b>No. 9</b>	20	<b>No. 24</b>	70
<b>No. 10</b>	5, 3	<b>No. 25</b>	70
<b>No. 11</b>	100	<b>No. 26</b>	130
<b>No. 12</b>	450	<b>No. 27</b>	10
<b>No. 13</b>	10, 5, 3	<b>No. 28</b>	100
<b>No. 14</b>	1100	<b>No. 29</b>	100
<b>No. 15</b>	250	<b>No. 30</b>	50

PHOTOGRAPH NO. 1 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #1



PHOTOGRAPH NO. 2 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #2




PHOTOGRAPH NO. 3 - EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #3



PHOTOGRAPH NO. 4 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #4



PHOTOGRAPH NO. 5 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #5



PHOTOGRAPH NO. 6 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #6



PHOTOGRAPH NO. 7 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #7



PHOTOGRAPH NO. 8 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #8



PHOTOGRAPH NO. 9 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #9



PHOTOGRAPH NO. 10 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #10



PHOTOGRAPH NO. 11 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #11



PHOTOGRAPH NO. 12 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #12



PHOTOGRAPH NO. 13 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #13



PHOTOGRAPH NO. 14 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #14



PHOTOGRAPH NO. 15 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #15



PHOTOGRAPH NO. 16 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #16



PHOTOGRAPH NO. 17 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #17



PHOTOGRAPH NO. 18 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #18



PHOTOGRAPH NO. 19 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #19



PHOTOGRAPH NO. 20 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #20




PHOTOGRAPH NO. 21 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #21



PHOTOGRAPH NO. 22 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #22



PHOTOGRAPH NO. 23 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #23



PHOTOGRAPH NO. 24 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #24



PHOTOGRAPH NO. 25 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #25



PHOTOGRAPH NO. 26 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #26



PHOTOGRAPH NO. 27 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #27



PHOTOGRAPH NO. 28 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #28



PHOTOGRAPH NO. 29 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #29




PHOTOGRAPH NO. 30 – EXTERNAL BOOM  
TYPICAL VIEW OF REPAIRED DEFECT #30



**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 5 – INTERNAL BAY #1:**



**TABLE 2.0 – INTERNAL BAY #1 REPAIRED DEFECTS:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	360 BC	No. 3	10 SW
No. 2	1200 SW	No. 4	800, 750 TC

TC = Top Chord  
BC = Bottom Chord

FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole

PHOTOGRAPH NO. 31 – INTERNAL BOOM BAY #1  
TYPICAL VIEW OF REPAIRED DEFECT #1



PHOTOGRAPH NO. 32 – INTERNAL BOOM BAY #1  
TYPICAL VIEW OF REPAIRED DEFECT #2



PHOTOGRAPH NO. 33 – INTERNAL BOOM BAY #1  
TYPICAL VIEW OF REPAIRED DEFECT #3




PHOTOGRAPH NO. 34 – INTERNAL BOOM BAY #1  
TYPICAL VIEW OF REPAIRED DEFECT #4



**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 6 – INTERNAL BAY #2:**



**TABLE 3.0 – INTERNAL BAY #2 REPAIRED DEFECTS:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	1300 SW	No. 6	40, 10 TC
No. 2	10 MH	No. 7	650 SW
No. 3	10 MH	No. 8	1700 TC
No. 4	1700 BC	No. 9	1700 BC
No. 5	1700 TC		

TC = Top Chord  
BC = Bottom Chord


FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole

PHOTOGRAPH NO. 35 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF REPAIRED DEFECT #1



PHOTOGRAPH NO. 36 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF REPAIRED DEFECT #2




PHOTOGRAPH NO. 37 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF REPAIRED DEFECT #3




PHOTOGRAPH NO. 38 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF REPAIRED DEFECT #4



PHOTOGRAPH NO. 39 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF REPAIRED DEFECT #5




PHOTOGRAPH NO. 40 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF REPAIRED DEFECT #6



PHOTOGRAPH NO. 41 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF REPAIRED DEFECT #7



PHOTOGRAPH NO. 42 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF REPAIRED DEFECT #8




PHOTOGRAPH NO. 43 – INTERNAL BOOM BAY #2  
TYPICAL VIEW OF REPAIRED DEFECT #9



INTENTIONALLY LEFT BLANK

**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 7 – INTERNAL BAY #3:**



**TABLE 4.0 – INTERNAL BAY #3 REPAIRED DEFECTS:**


<b>Defect No.</b>	<b>Length in mm</b>	<b>Defect No.</b>	<b>Length in mm</b>
<b>No. 1</b>	500 SW	<b>No. 6</b>	1400 SW
<b>No. 2</b>	700 SW	<b>No. 7</b>	1500 TC
<b>No. 3</b>	1500 TC	<b>No. 8</b>	600 SW
<b>No. 4</b>	1400 SW	<b>No. 9</b>	600 SW
<b>No. 5</b>	1500 BC	<b>No. 10</b>	1500 BC

TC = Top Chord  
BC = Bottom Chord

FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole


PHOTOGRAPH NO. 44 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF REPAIRED DEFECT #1




PHOTOGRAPH NO. 45 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF REPAIRED DEFECT #2




PHOTOGRAPH NO. 46 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF REPAIRED DEFECT #3




PHOTOGRAPH NO. 47 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF REPAIRED DEFECT #4



PHOTOGRAPH NO. 48 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF REPAIRED DEFECT #5



PHOTOGRAPH NO. 49 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF REPAIRED DEFECT #6



PHOTOGRAPH NO. 50 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF REPAIRED DEFECT #7



PHOTOGRAPH NO. 51 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF REPAIRED DEFECT #8



PHOTOGRAPH NO. 52 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF REPAIRED DEFECT #9




PHOTOGRAPH NO. 53 – INTERNAL BOOM BAY #3  
TYPICAL VIEW OF REPAIRED DEFECT #10



**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 8 – INTERNAL BAY #4:**



**TABLE 5.0 – INTERNAL BAY #4 REPAIRED DEFECTS:**


Defect No.	Length in mm	Defect No.	Length in mm
No. 1	1800 SW	No. 7	1000 SW
No. 2	50 TC	No. 8	50 TC
No. 3	1400 TC	No. 9	600 BC
No. 4	1500 BC	No. 10	1800 SW
No. 5	2800 TC/SW	No. 11	100 MH
No. 6	2800 TC/SW		

TC = Top Chord  
BC = Bottom Chord


FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole


PHOTOGRAPH NO. 54 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #1



PHOTOGRAPH NO. 55 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #2




PHOTOGRAPH NO. 56 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #3



PHOTOGRAPH NO. 57 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #4




PHOTOGRAPH NO. 58 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #5




PHOTOGRAPH NO. 59 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #6



PHOTOGRAPH NO. 60 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #7




PHOTOGRAPH NO. 61 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #8



PHOTOGRAPH NO. 62 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #9



PHOTOGRAPH NO. 63 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #10




PHOTOGRAPH NO. 64 – INTERNAL BOOM BAY #4  
TYPICAL VIEW OF REPAIRED DEFECT #11



INTENTIONALLY LEFT BLANK

**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 9 – INTERNAL BAY #5:**



**TABLE 6.0 – INTERNAL BAY #5 REPAIRED DEFECTS:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	600 TC	No. 8	2200 TT/SW
No. 2	400 SW	No. 9	3600 BC
No. 3	200 SW	No. 10	3600 BC
No. 4	150 SW	No. 11	1100 TC
No. 5	600 TC	No. 12	300 TC
No. 6	200 TT	No. 13	300 TC
No. 7	1000 TT/SW		

TC = Top Chord  
 BC = Bottom Chord  
 TT = Torque Tube

FW = Front Wall  
 RW = Rear Wall

SW = Side Wall  
 MH = Man Hole

PHOTOGRAPH NO. 65 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #1



PHOTOGRAPH NO. 66 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #2




PHOTOGRAPH NO. 67 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #3



PHOTOGRAPH NO. 68 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #4



PHOTOGRAPH NO. 69 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #5



PHOTOGRAPH NO. 70 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #6



PHOTOGRAPH NO. 71 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #7



PHOTOGRAPH NO. 72 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #8



PHOTOGRAPH NO. 73 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #9



PHOTOGRAPH NO. 74 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #10




PHOTOGRAPH NO. 75 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #11



PHOTOGRAPH NO. 76 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #12




PHOTOGRAPH NO. 77 – INTERNAL BOOM BAY #5  
TYPICAL VIEW OF REPAIRED DEFECT #13



INTENTIONALLY LEFT BLANK

**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 10 – INTERNAL BAY #6:**



**TABLE 7.0 – INTERNAL BAY #6 REPAIRED DEFECTS:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	370 BC	No. 7	360 TC
No. 2	130 MH	No. 8	80 TC
No. 3	140 SW	No. 9	60 TC
No. 4	90 SW	No. 10	120 MH
No. 5	220 MH	No. 11	170 TC
No. 6	30 SW	No. 12	70, 60 TC

TC = Top Chord  
BC = Bottom Chord

FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole


PHOTOGRAPH NO. 78 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #1




PHOTOGRAPH NO. 79 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #2



PHOTOGRAPH NO. 80 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #3



PHOTOGRAPH NO. 81 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #4



PHOTOGRAPH NO. 82 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #5




PHOTOGRAPH NO. 83 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #6



PHOTOGRAPH NO. 84 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #7




PHOTOGRAPH NO. 85 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #8



PHOTOGRAPH NO. 86 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #9



PHOTOGRAPH NO. 87 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #10



PHOTOGRAPH NO. 88 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #11




PHOTOGRAPH NO. 89 – INTERNAL BOOM BAY #6  
TYPICAL VIEW OF REPAIRED DEFECT #12



**RESULTS OF EXAMINATION CONTINUED**

**FIGURE 11 – INTERNAL BAY #7:**



**TABLE 8.0 – INTERNAL BAY #7 REPAIRED DEFECTS:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	150 BC	No. 6	530 SW
No. 2	190 BC	No. 7	1200 SW
No. 3	1150 SW	No. 8	170 TC
No. 4	250 TC	No. 9	720 TC
No. 5	350 MH		

TC = Top Chord  
BC = Bottom Chord


FW = Front Wall  
RW = Rear Wall

SW = Side Wall  
MH = Man Hole

PHOTOGRAPH NO. 90 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF REPAIRED DEFECT #1 & #2



PHOTOGRAPH NO. 91 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF REPAIRED DEFECT #3




PHOTOGRAPH NO. 92 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF REPAIRED DEFECT #4



PHOTOGRAPH NO. 93 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF REPAIRED DEFECT #5



PHOTOGRAPH NO. 94 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF REPAIRED DEFECT #6



PHOTOGRAPH NO. 95 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF REPAIRED DEFECT #7



PHOTOGRAPH NO. 96 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF REPAIRED DEFECT #8




PHOTOGRAPH NO. 97 – INTERNAL BOOM BAY #7  
TYPICAL VIEW OF REPAIRED DEFECT #9



**RESULTS OF EXAMINATION CONTINUED**


**FIGURE 12 – INTERNAL BAY #8:**



**TABLE 9.0 – INTERNAL BAY #8 REPAIRED DEFECTS:**

Defect No.	Length in mm	Defect No.	Length in mm
No. 1	350 BC	No. 3	40 TC
No. 2	650, 1100 SW	No. 4	750 TC

PHOTOGRAPH NO. 98 – INTERNAL BOOM BAY #8  
TYPICAL VIEW OF REPAIRED DEFECT #1



PHOTOGRAPH NO. 99 – INTERNAL BOOM BAY #8  
TYPICAL VIEW OF REPAIRED DEFECT #2



PHOTOGRAPH NO. 100 – INTERNAL BOOM BAY #8  
TYPICAL VIEW OF REPAIRED DEFECT #3



PHOTOGRAPH NO. 101 – INTERNAL BOOM BAY #8  
TYPICAL VIEW OF REPAIRED DEFECT #4



PHOTOGRAPH NO. 102 – GENERAL VIEW OF NEW MAN HOLE COVER



PHOTOGRAPH NO. 103 – GENERAL VIEW OF NEW MAN HOLE COVER



PHOTOGRAPH NO. 104 – GENERAL VIEW OF NEW MAN HOLE COVER



INTENTIONALLY LEFT BLANK

PHOTOGRAPH NO. 105 – GENERAL VIEW OF EX5600 BOOM



PHOTOGRAPH NO. 106 – GENERAL VIEW OF EX5600 BOOM



PHOTOGRAPH NO. 107 – GENERAL VIEW OF EX5600 BOOM



PHOTOGRAPH NO. 108 – GENERAL VIEW OF EX5600 BOOM



*Section 5*

# WELDING RECORDS/PROCEDURES

Document Name	Document ID	Version	Issue Date	Page
Workshop MDR	F_QA-013	1	10.02.2019	Page 7 of 9

# WELDING PROCEDURE SPECIFICATION



WELDING PROCEDURE SPECIFICATION NUMBER		WMS_WPS-002	
<b>Code / Standard:</b>	AS/NZS 1554.1 SP	<b>Edge Preparation:</b>	Flame Cut & Grind or Machined
<b>Process:</b>	FCAW	<b>Power Source:</b>	DC Constant Voltage Transformer or Inverter
<b>Joint Type:</b>	Single-V Butt Weld With Backing	<b>Technique:</b>	Stringer
<b>Joint Position:</b>	4G (PE)	<b>Multi-run or Single:</b>	Multi
<b>Positions Qualified:</b>	1G (PA), 2G (PC) & 4G (PE)	<b>Torch Angle:</b>	5° Drag
<b>PQR Number:</b>	PQR-CQFMS-002	<b>Inter Pass Cleaning:</b>	Grind & Brush
<b>Revision:</b>	1	<b>Root Opening:</b>	6mm (AS1554 ± 1.5)
<b>Date Issued:</b>	18/02/16	<b>Root Face:</b>	0mm (AS1554 ± 1.5)
<b>Welder:</b>	Sam Currell	<b>Grove Angle:</b>	30° Included (AS1554 +10° to -5°)
<b>Location:</b>	CQ Field Facility Mackay	<b>Backing:</b>	6mm Gr250 Flat Bar

## WELDING CONSUMABLE DETAIL


Consumable No 1		Consumable No 2		Shield Gas/Flux	
Classification/Grade:	B T 49 3 T12 1 C A U H10 B T	Classification/Grade:	NA	Shield Gas:	Argoshield Universal
Diameter:	1.6mm	Diameter:	NA	Flow Rate:	20L/M +≥25%/-≥10%
Trade Name:	CIGWELD Verti-cor 3xp	Trade Name:	NA	Purge Rate:	N/A
Batch #:	2001402075	Batch #:	NA	Flux:	N/A
Stickout:	15-20mm	Stickout:	NA		

WELD PREPARATION		SEQUENCE/POSITION		MATERIAL SPECIFICATION				
		<p style="text-align: center;">Side 1</p> <p style="text-align: center;">Number of weld passes are indicative to nominated weld procedure and may vary</p>		<b>TYPE/GRADE</b>	<b>GROUP</b>	<b>T</b>	<b>Diameter</b>	
				AS 1554		mm	mm	
				1	AS/NZS 3678 Gr. 350	5	20	N/A
				2	AS/NZS 3678 Gr. 350	5	20	N/A
				RANGE QUALIFIED		AS 1554: 10mm to 40mm		
				<b>THERMAL TREATMENT</b>				
				PREHEAT:		50°C		
				MAX INTERPASS:		175°C		
				P.W.H.T.:		NIL		

WELD PASS DETAILS					ELECTRODE DESCRIPTION		PREHEAT	WELDING PARAMETERS									
PROCESS	PASS NO.	SIDE NO.	POS	DIR	TYPE	ELECTRODE SIZE mm	SPEC	TEMP °C	AMPS		VOLTS		POL	TRAVEL SPEED (mm/min)		HEAT INPUT (KJ/mm)	
									Min	Max	Min	Max		Min	Max	Min	Max
FCAW Root & Hot Pass	1 - 2	1	4G (PE)	Drag	136	1.6mm	A5.20: E71T-1 H8	50	234.5	286.6	22.9	26.3	DC+	206.9	279.9	1.42	1.74
									<b>Actual 260.5</b>		<b>Actual 24.6</b>		<b>Actual 243.4</b>		<b>Actual 1.58</b>		
FCAW Fill	2 - 9	1	4G (PE)	Drag	136	1.6mm	A5.20: E71T-1 H8	50	238.1	291.0	22.8	26.2	DC+	311.1	420.9	0.96	1.18
									<b>Actual 264.6</b>		<b>Actual 24.5</b>		<b>Actual 366.0</b>		<b>Actual 1.07</b>		
FCAW Cap	10 - 12	1	4G (PE)	Drag	136	1.6mm	A5.20: E71T-1 H8	50	240.0	293.3	22.9	26.3	DC+	306.1	414.1	0.99	1.21
									<b>Actual 266.7</b>		<b>Actual 24.6</b>		<b>Actual 360.1</b>		<b>Actual 1.10</b>		

TESTING REQUIRED & RESULTS			NOTES			
Refer to supporting PQR for the following testing reports:			Preheat - Ensure preheat is applied according to the relevant material within the group and/or the combined joint thickness as per preheat calculations outlined in WTIA Tech Note 1 for compliance to AS 1554.1. - Interpass temperature is limited due to CVN impact requirements and temper preservation for this material.  General - Ensure joints are free from contaminants during welding process.			
Visual	CQVE-007					
Mechanical:	M16-0310 A					
NDT:	M16-0310 A					
Chemical:	7476829 & 7454009		MINIMUM PREHEAT & MAXIMUM INTERPASS TEMP Gr. 350			
			THICKNESS	PREHEAT	INTERPASS	
			≥26<50	50°C	175°C	
			≥50<100	75°C	200°C	
			≥100	140°C	220°C	

<b>Complied By:</b>	Michael Barnes -CQ Field Mining Services-	<b>Reviewed By:</b>	Craig Evans -iScope-	<b>Reviewed By:</b>	
<b>Signed:</b>		<b>Signed:</b>		<b>Signed:</b>	
WTIA AU/IWS/00569 WTIA SS-19900		WTIA AU/IWS/6082 / WTIA SS-2054 / AU/IWI B/00746			



iScope certify that the statements in this record are correct and that the test welds were prepared, welded, and tested in accordance with the requirements of the standard and category specifications.

# WELDING PROCEDURE SPECIFICATION



WELDING PROCEDURE SPECIFICATION NUMBER		WMS_WPS-032	
<b>Code / Standard:</b>	AS/NZS 1554.1 SP	<b>Edge Preparation:</b>	Flame Cut & Grind or Machined
<b>Process:</b>	FCAW	<b>Power Source:</b>	DC Constant Voltage Transformer or Inverter
<b>Joint Type:</b>	Single Bevel Butt With Backing (BW,ss,mb)	<b>Technique:</b>	Stringer
<b>Joint Position:</b>	4G (PE)	<b>Multi-run or Single:</b>	Multi
<b>Positions Qualified:</b>	1G (PA), 2G (PC) & 4G (PD & PE)	<b>Torch Angle:</b>	5° Drag
<b>PQR Number:</b>	IS4R-WPQR-003	<b>Inter Pass Cleaning:</b>	Grind & Brush
<b>Revision:</b>	0	<b>Root Opening (G):</b>	6mm
<b>Date Issued:</b>	02/03/20	<b>Root Face (F):</b>	0mm
<b>Welder:</b>	Craig Evans	<b>Grove Angle (DEG):</b>	45° Included (AS1554 +10° to -5°)
<b>Location:</b>	Mackay Facility	<b>Backing:</b>	6mm GR250 plate

## WELDING CONSUMABLE DETAIL


Consumable No 1		Consumable No 2		Shield Gas/Flux	
Classification/Grade:	B T 49 3 T12 1 C A U H10	Classification/Grade:	NA	Shield Gas:	Argosshield 52 - Ar+25% CO
Diameter:	1.6mm	Diameter:	NA	Flow Rate:	20L/M +≥25%/-≥10%
Trade Name:	Verti-Cor 3XP E71T-1 H8	Trade Name:	NA	Purge Rate:	N/A
Batch #:	7486	Batch #:	NA	Flux:	N/A
Stickout:	15-20mm	Stickout:	NA		

WELD PREPARATION	SEQUENCE/POSITION	MATERIAL SPECIFICATION					
	Side 1		<b>TYPE/GRADE</b>	<b>GROUP</b>	<b>T</b>	<b>Diameter</b>	
	Side 2		AS 1554	mm	mm		
			1	AS/NZS 3678 Gr. 350	5	12	N/A
			2	AS/NZS 3678 Gr. 350	5	12	N/A
			RANGE QUALIFIED	AS 1554.1: 6mm to 25mm			
			<b>THERMAL TREATMENT</b>				
			PREHEAT:	50°C			
			MAX INTERPASS:	175°C			
			P.W.H.T.:	NIL			

WELD PASS DETAILS					ELECTRODE DESCRIPTION		PREHEAT	WELDING PARAMETERS									
PROCESS	PASS NO.	SIDE NO.	POS	DIR	TYPE	ELECTRODE SIZE mm	SPEC	TEMP °C	AMPS		VOLTS		POL	TRAVEL SPEED (mm/min)		HEAT INPUT (KJ/mm)	
									Min	Max	Min	Max		Min	Max	Min	Max
FCAW Root	1	1	3G	Up	136	1.6mm	Verti-Cor 3XP E71T-1 H8	50°C	Actual -10%	Actual +10%	Actual -7%	Actual +7%	DC+	Actual -15%	Actual +15%	Actual -10%	Actual +10%
									214.2	261.8	22.5	25.9		332.4	449.7	0.8	1.0
									<b>Actual 238</b>		<b>Actual 24.2</b>			<b>Actual 391</b>		<b>Actual 0.88</b>	
FCAW Hot Pass	2-3	1	3G	Up	136	1.6mm	Verti-Cor 3XP E71T-1 H8	50°C	199.8	244.2	22.5	25.9	DC+	303.0	410.0	0.8	1.0
									<b>Actual 222</b>		<b>Actual 24.2</b>			<b>Actual 356.5</b>		<b>Actual 0.91</b>	
FCAW Fill	4-6	1	3G	Up	136	1.6mm	Verti-Cor 3XP E71T-1 H8	50°C	205.7	251.46	22.5	25.9	DC+	279.7	378.4	0.9	1.1
									<b>Actual 228.6</b>		<b>Actual 24.2</b>			<b>Actual 329</b>		<b>Actual 1.01</b>	
FCAW Cap	7-9	1	3G	Up	136	1.6mm	Verti-Cor 3XP E71T-1 H8	50°C	192.9	235.73	22.5	25.9	DC+	261.0	353.1	0.9	1.2
									<b>Actual 214.3</b>		<b>Actual 24.2</b>			<b>Actual 307</b>		<b>Actual 1.05</b>	

TESTING REQUIRED & RESULTS	NOTES		
Refer to supporting PQR for the following testing reports:  Visual: IS4R-RPT-0087 Mechanical: IS4R-RPT-0085 NDT: M21-1118 Chemical: BE00027892/MC/PK/XII/19	Preheat - Ensure preheat is applied according to the relevant material within the group and/or the combined joint thickness as per preheat calculations outlined in WTIA Tech Note 1 for compliance to AS 1554.1. - Interpass temperature is limited due to CVN impact requirements and temper preservation for this material.  General - Ensure joints are free from contaminants.		
	MINIMUM PREHEAT & MAXIMUM INTERPASS TEMP Gr. 350		
	THICKNESS	PREHEAT	INTERPASS
	≥26<50	50°C	175°C
	≥50<100	75°C	200°C
	≥100	140°C	220°C

<b>Complied By:</b>	Clancy Crerar -iScope-	<b>Reviewed By:</b>	Craig Evans -iScope-	<b>Reviewed By:</b>	
<b>Signed:</b>		<b>Signed:</b>		<b>Signed:</b>	
	AU/IWI B/0895		WTIA AU/IWS/6082 / WTIA SS-2054 / AU/IWI B/00746		



iScope certify that the statements in this record are correct and that the test welds were prepared, welded, and tested in accordance with the requirements of the standard and category specifications.

# WELDING PROCEDURE SPECIFICATION



WELDING PROCEDURE SPECIFICATION NUMBER		WMS_WPS-062	
<b>Code / Standard:</b>	AS/NZS 1554.5	<b>Edge Preparation:</b>	Flame Cut & Grind or Machined
<b>Process:</b>	FCAW	<b>Power Source:</b>	DC Constant Voltage Transformer or Inverter
<b>Joint Type:</b>	F1 Fillet	<b>Technique:</b>	Stringer
<b>Joint Position:</b>	4F (PD)	<b>Multi-run or Single:</b>	Single
<b>Positions Qualified:</b>	1F (PA), 2F (PB) & 4F (PD)	<b>Torch Angle:</b>	5° Drag
<b>PQR Number:</b>	R-WPQR-FCAW23	<b>Inter Pass Cleaning:</b>	Grind & Brush
<b>Revision:</b>	0	<b>Root Opening:</b>	0mm
<b>Date Issued:</b>	19/07/22	<b>Root Face:</b>	0mm
<b>Welder:</b>	Bradley Jenkins	<b>Grove Angle:</b>	90° Included (AS1554 +10° to -5°)
<b>Location:</b>	Mackay Facility	<b>Backing:</b>	Nil

## WELDING CONSUMABLE DETAIL

Consumable No 1		Consumable No 2		Shield Gas/Flux	
Classification/Grade:	B T 49 3 T12 1 M A N2 U H5	Classification/Grade:	NA	Shield Gas:	25% CO 75% Argon
Diameter:	1.6mm	Diameter:	NA	Flow Rate:	20L/M +≥25%/≥10%
Trade Name:	Verti-Cor 3XP E71T-12M H4	Trade Name:	NA	Purge Rate:	N/A
Batch #:	7486	Batch #:	NA	Flux:	N/A
Stickout:	15-20mm	Stickout:	NA		

WELD PREPARATION	SEQUENCE/POSITION	MATERIAL SPECIFICATION				
	<p style="text-align: center;">Number of weld passes are indicative to nominated weld procedure and may vary</p>	<b>TYPE/GRADE</b>	<b>GROUP</b>	<b>T</b>	<b>Diameter</b>	
			AS 1554	mm	mm	
		1	AS/NZS 3678 Gr. 350	5	12	N/A
		2	AS/NZS 3678 Gr. 350	5	12	N/A
	RANGE QUALIFIED	AS 1554: 3mm to Unlimited				
<b>THERMAL TREATMENT</b>						
	PREHEAT:	50°C				
	MAX INTERPASS:	150°C				
	P.W.H.T.:	NIL				

WELD PASS DETAILS					ELECTRODE DESCRIPTION			PREHEAT	WELDING PARAMETERS								
PROCESS	PASS NO.	SIDE NO.	POS	DIR	TYPE	ELECTRODE SIZE mm	SPEC	TEMP °C	AMPS		VOLTS		POL	TRAVEL SPEED (mm/min)		HEAT INPUT (KJ/mm)	
									Min	Max	Min	Max		Min	Max	Min	Max
									Actual -10%	Actual +10%	Actual -7%	Actual +7%		Actual -15%	Actual +15%	Actual -10%	Actual +10%
FCAW	1	1	4F (PD)	Drag	136	1.6mm	Verti-Cor 3XP E71T-12M H4	50°C	246.6	301.4	21.5	24.7	DC+	201.3	272.3	1.44	1.76
									Actual 274.0		Actual 23.1			Actual 236.8		Actual 1.60	

TESTING REQUIRED & RESULTS	NOTES		
Refer to supporting PQR for the following testing reports: Visual: IS4R-RPT-1456 Mechanical: M20-1335-02 NDT: NA Chemical: T11776	Preheat - Ensure preheat is applied according to the relevant material within the group and/or the combined joint thickness as per preheat calculations outlined in WTIA Tech Note 1 for compliance to AS 1554.5. - Interpass temperature is limited due to CVN impact requirements and temper preservation for this material.		MINIMUM PREHEAT & MAXIMUM INTERPASS TEMP Gr. 350
	General		THICKNESS
	- Ensure joints are free from contaminants.		PREHEAT
	- Material, consumable & joint type are prequalified as per AS 1554.5		INTERPASS
	- WPS may be used on nominated CAT & Liebherr Castings as per Spectro reports M22-1185-02 & M22-1185-03.		≥26<50
			50°C
			175°C
			≥50<100
			75°C
			200°C
			≥100
			140°C
			220°C

<b>Complied By:</b>	Clancy Crerar -iScope4Repair-	<b>Reviewed By:</b>	Craig Evans -iScope4Repair-
<b>Signed:</b>		<b>Signed:</b>	
	AU/IWI B/0895 / CC184154-02		WTIA AU/IWS/6082 / WTIA SS-2054 / AU/IWI B/00746

iScope4Repair certify that the statements in this record are correct and that the test welds were prepared, welded, and tested in accordance with the requirements of the standard and category specifications.



# WELDING PROCEDURE SPECIFICATION




WELDING PROCEDURE SPECIFICATION NUMBER		WMS_WPS-068	
<b>Code / Standard:</b>	AS/NZS 1554.5	<b>Edge Preparation:</b>	Flame Cut & Grind or Machined
<b>Process:</b>	FCAW	<b>Power Source:</b>	DC Constant Voltage Transformer or Inverter
<b>Joint Type:</b>	F1 Fillet	<b>Technique:</b>	Stringer
<b>Joint Position:</b>	3F (PF)	<b>Torch Angle:</b>	5° Push
<b>Positions Qualified:</b>	3F (PF)	<b>Inter Pass Cleaning:</b>	Grind & Brush
<b>Multi-run or Single:</b>	Multi	<b>Root Opening:</b>	0mm
<b>PQR Number:</b>	R-WPQR-FCAW3	<b>Root Face:</b>	0mm
<b>Revision:</b>	0	<b>Grove Angle:</b>	90° Included
<b>Date Issued:</b>	21/06/2023	<b>Backing:</b>	Nil


## WELDING CONSUMABLE DETAIL

Consumable No 1		Consumable No 2		Shield Gas/Flux	
Classification/Grade: AS/NZS ISO 14341	B T 49 3 T12 1 M A N2 U H5	Classification/Grade: AS/NZS ISO 14341	N/A	Shield Gas Composition: ISO 14175	M26-ArCO-16/2.75
Diameter:	1.6mm	Diameter:	N/A	Flow Rate:	18-25 L/M
Trade Name:	Verti-Cor 3XP E71T-12M H4	Trade Name:	N/A	Purge Rate:	N/A
Stickout:	15-20mm	Stickout:	N/A	Flux:	N/A

## WELD PREPARATION



## SEQUENCE/POSITION



Number of weld passes are indicative to nominated weld procedure and may vary

## MATERIAL SPECIFICATION

	TYPE/GRADE	GROUP	T	Diameter
		AS 1554	mm	mm
1	AS3678 Gr350	Steel Type: 1, 2, 4, 5 Weldability Group: ≤6	12	NA
2	AS3678 Gr350	Steel Type: 1, 2, 4, 5 Weldability Group: ≤6	12	NA
RANGE QUALIFIED				
Thickness: Unlimited				
THERMAL TREATMENT				
PREHEAT:		Refer to Table in Notes		
MAX INTERPASS:		180°C		

## WELD PASS DETAILS

## ELECTRODE DESCRIPTION

## PREHEAT

## WELDING PARAMETERS

PROCESS	PASS NO.	SIDE NO.	POS	DIR	TYPE	ELECTRODE SIZE mm	SPEC	TEMP °C	AMPS				VOLTS		POL	TRAVEL SPEED (mm/min)		HEAT INPUT (KJ/mm)	
									Min		Max		Min	Max		Min	Max	Min	Max
									Actual -10%	Actual +10%	Actual -7%	Actual +7%	Actual -15%	Actual +15%		Min	Max		
FCAW Root	1	1	3F (PF)	Up	136	1.6mm	A5.20 E71T-12M H4	50°C	252.0	308.0	21.3	24.5	DC+	194	262	1.23	2.34		
									<b>Actual 280</b>		<b>Actual 22.9</b>		<b>Actual 227.8</b>		<b>Actual 1.78</b>				
FCAW Cap	2 & 3	1	3F (PF)	Up	136	1.6mm	A5.20 E71T-12M H4	50°C	245.7	300.3	21.7	24.9	DC+	241	326	0.98	1.86		
									<b>Actual 273</b>		<b>Actual 23.3</b>		<b>Actual 283.6</b>		<b>Actual 1.42</b>				

## NOTES

<p><b>Preheat</b></p> <ul style="list-style-type: none"> <li>- Ensure preheat is applied according to the relevant material within the group and/or the combined joint thickness as per preheat calculations outlined in WTIA Tech Note 1 for compliance to AS 1554.5.</li> <li>- Interpass temperature is limited due to CVN impact requirements and temper preservation for this material.</li> </ul> <p><b>General</b></p> <ul style="list-style-type: none"> <li>- Ensure joints are free from contaminants.</li> <li>- Grind all layers to clean material eliminating all surface indications.</li> </ul>	<p>MINIMUM PREHEAT &amp; MAXIMUM INTERPASS TEMP Gr350</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>CJT</th> <th>PREHEAT</th> <th>INTERPASS</th> </tr> </thead> <tbody> <tr> <td>&lt;50</td> <td>50°C</td> <td>180°C</td> </tr> <tr> <td>≥50&lt;100</td> <td>75°C</td> <td>220°C</td> </tr> <tr> <td>≥100</td> <td>140°C</td> <td>220°C</td> </tr> </tbody> </table>	CJT	PREHEAT	INTERPASS	<50	50°C	180°C	≥50<100	75°C	220°C	≥100	140°C	220°C
CJT	PREHEAT	INTERPASS											
<50	50°C	180°C											
≥50<100	75°C	220°C											
≥100	140°C	220°C											

<b>Complied By:</b> Clancy Crerar -iScope- Signed:	<b>Reviewed By:</b> Craig Evans -iScope- Signed:	<b>Reviewed By:</b> Signed:
AU/IWI B/0895 / CC184154-02	WTIA AU/IWS/6082 / WTIA SS-2054 / AU/IWI B/0895	

iScope certify that the statements in this record are correct and that the test welds were prepared, welded, and tested in accordance with the requirements of the standard and category specifications.

*Row*



**WELDING & PRE-HEAT RECORD SHEET**

Client:	Minespec	Job No:	27861	Date:		Weld Procedure:	WPS-062, 064, 068
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish			

Job Description:	Refurbish Minespec 5600 Boom	Drawing No:	
------------------	------------------------------	-------------	--

Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
264			100	105	12/12/23	6AM	23.5	190	376	3XP E71T1-H8			
264			100	103	12/12/23	7AM	23.5	190	376	3XP E71T1-H8			
264	1F		100	110	12/12/23	8AM	23.5	190	376	3XP E71T1-H8			
264		WPS-062	100	108	12/12/23	9AM	23.5	190	376	3XP E71T1-H8			
264	2F		100	111	12/12/23	10AM	23.5	190	376	3XP E71T1-H8			
264			100	108	12/12/23	11AM	23.5	190	376	3XP E71T1-H8			
264	3F	WPS-068	100	113	12/12/23	12pm	23.5	190	376	3XP E71T1-H8			
264			100	115	12/12/23	1pm	23.5	190	376	3XP E71T1-H8			
264			100	107	12/12/23	2pm	23.5	190	376	3XP E71T1-H8			
264			100	108	12/12/23	3pm	23.5	190	376	3XP E71T1-H8			
264			100	112	12/12/23	4pm	23.5	190	376	3XP E71T1-H8			
264			100	118	12/12/23	5pm	23.5	190	376	3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

**PRE-HEAT and CONSUMABLE GUIDE**

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

**WELDING & PRE-HEAT RECORD SHEET**

Client:	Minespec	Job No:	27861	Date:		Weld Procedure:	WPS-062, 064, 068						
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish									
Job Description:	Refurbish Minespec 5600 Boom			Drawing No:	BAY 8								
Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
CQ214	1F  2F  3F	WPS-062	100°C	120°C	13-12	6:00	27.4	220	W579	3XP E71T1-H8			
CQ214			130°C	13-12	7:00	27.6				3XP E71T1-H8	200151083		BIMAL BASIL
			125°C	13-12	8:00	27.4				3XP E71T1-H8			
			122°C	13-12	9:00	27.4				3XP E71T1-H8			
			123°C	13-12	10:30	27.4				3XP E71T1-H8			
			115°C	13-12	11:30	27.4				3XP E71T1-H8			
			120°C	13-12	12:30	27.4				3XP E71T1-H8			
			117°C	13-12	1:30	27.4				3XP E71T1-H8			
			120°C	13-12	2:30	27.4				3XP E71T1-H8			
			115°C	13-12	3:30	27.4				3XP E71T1-H8			
214				112	13-12	4:06	27.4	220		3XP E71T1-H8	200151083		
										3XP E71T1-H8	20		

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

**PRE-HEAT and CONSUMABLE GUIDE**

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

Row



WELDING & PRE-HEAT RECORD SHEET

Client:	Minespec	Job No:	27861	Date:		Weld Procedure:	WPS-062, 064, 068						
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish									
Job Description:	Refurbish Minespec 5600 Boom			Drawing No:									
Welder ID	Joint Type/ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
264			100	105	13/12/23	7AM	23.5	180	376	3XP E71T1-H8			
264			100	110	13/12/23	8AM	23.5	180	376	3XP E71T1-H8			
264	1F	WPS-062	100	107	13/12/23	9AM	23.5	180	376	3XP E71T1-H8			
264			100	112	13/12/23	10AM	23.5	180	376	3XP E71T1-H8			
264	2F		100	115	13/12/23	11AM	23.5	180	376	3XP E71T1-H8		DIAMAL	
264		100	108	13/12/23	12PM	23.5	180	376	3XP E71T1-H8				
264	3F	WPS-068	100	103	13/12/23	1pm	23.5	180	376	3XP E71T1-H8		BASIL	
264			100	113	13/12/23	2pm	23.5	180	376	3XP E71T1-H8			
264			100	108	13/12/23	3pm	23.5	180	376	3XP E71T1-H8			
264			100	110	13/12/23	4pm	23.5	180	376	3XP E71T1-H8			
264			100	112	13/12/23	5pm	23.5	180	376	3XP E71T1-H8			
264			100	115	13/12/23	6pm	23.5	180	376	3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

**WELDING & PRE-HEAT RECORD SHEET**

Client:	Minespec	Job No:	27861	Date:	14.12.23	Weld Procedure:	LOPS - 062, 064, 068
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish			

Job Description:		Refurbish Minespec 5600 Boom					Drawing No:		BAY 2				
Welder ID	Joint Type/ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
214			100°C	120°C	14.12	4:30	27.4	220	0574	3XP E71T1-H8			
214				123°C		7:30	27.4	220		3XP E71T1-H8	200151083		
	1F	WPS-062		125°C		8:30	27.4	221		3XP E71T1-H8			
				123°C		9:30	27.4	220		3XP E71T1-H8			
				115°C		10:30	27.4	200		3XP E71T1-H8		BIMAC	
	2.F			112°C		11:30	27.4	220		3XP E71T1-H8		B51C	B
		WPS-068		117°C		12:30	27.4	220		3XP E71T1-H8			
				119°C		1:30	27.4	220		3XP E71T1-H8			
	3F			111°C		2:30	27.4	225		3XP E71T1-H8			
				113°C		3:30	27.4	214		3XP E71T1-H8			
214				199°C	14.12	4:30	27.4	220	0574	3XP E71T1-H8	200151083		
										3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

**PRE-HEAT and CONSUMABLE GUIDE**

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

Row



WELDING & PRE-HEAT RECORD SHEET

Client:	Minespec	Job No:	27861	Date:		Weld Procedure:	WPS-062, 064, 068
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish			

Job Description:	Refurbish Minespec 5600 Boom	Drawing No:	
------------------	------------------------------	-------------	--

Welder ID	Joint Type/ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
264			100	103	14/12/23	7AM	24	190	376	3XP E71T1-H8			
264			100	105	14/12/23	8AM	24	190	376	3XP E71T1-H8			
264	1A	WPS-062	100	110	14/12/23	9AM	24	190	376	3XP E71T1-H8			
264			100	115	14/12/23	10AM	24	190	376	3XP E71T1-H8			
264	2A		100	104	14/12/23	11AM	24	190	376	3XP E71T1-H8			
264			100	108	14/12/23	12PM	24	190	376	3XP E71T1-H8			
264			100	111	14/12/23	1PM	24	190	376	3XP E71T1-H8			
264			100	117	14/12/23	2PM	24	190	376	3XP E71T1-H8			
264	3A	WPS-068	100	112	14/12/23	3PM	24	190	376	3XP E71T1-H8			
264			100	104	14/12/23	4PM	24	190	376	3XP E71T1-H8			
264			100	111	14/12/23	5PM	24	190	376	3XP E71T1-H8			
264			100	112	14/12/23	6PM	24	190	376	3XP E71T1-H8			

BIMAC  
BASIC

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm<	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

Uncontrolled If Printed

**WELDING & PRE-HEAT RECORD SHEET**

Client:	Minespec	Job No:	27861	Date:	14/12/24	Weld Procedure:	WOPS-062,064,068
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish			

Job Description:		Refurbish Minespec 5600 Boom					Drawing No:						
Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
352			100°C	107°C	14/12/24	6:00 AM	24.2	218	WS720	3XP E71T1-H8	2001416063		
352	1		100°C	105°C		7:00 AM	24.2	218	WS720	3XP E71T1-H8	2001416063		
352	G		100°C	103°C		8:00 AM	24.2	218	WS720	3XP E71T1-H8	2001416063		
352		WOPS-062	100°C	106°C		9:00 AM	23.2	165	WS720	3XP E71T1-H8	2001416063		
352	2		100°C	104°C		10:00 AM	23.2	165	WS720	3XP E71T1-H8	2001416063		
352	G	WOPS-068	100°C	102°C		11:00 AM	23.2	165	WS720	3XP E71T1-H8	2001416063	Bimal	
352			100°C	106°C		12:00 PM	23.2	165	WS720	3XP E71T1-H8	2001416063	BASIL	
352			100°C	105°C		1:00 PM	24.2	218	WS720	3XP E71T1-H8	2001416063		
352	3		100°C	102°C		2:00 PM	24.2	218	WS720	3XP E71T1-H8	2001416063		
352	G		100°C	107°C		3:00 PM	24.2	218	WS720	3XP E71T1-H8	2001416063		
352			100°C	106°C		4:00 PM	23.2	165	WS720	3XP E71T1-H8	2001416063		
										3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

**PRE-HEAT and CONSUMABLE GUIDE**

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

## WELDING & PRE-HEAT RECORD SHEET

Client:	Minespec	Job No:	27861	Date:	15/1/23	Weld Procedure:	WPS-062, 064, 069
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish			

Job Description:			Refurbish Minespec 5600 Boom				Drawing No:						
Welder ID	Joint Type/ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
352			100°C	105°C		6:20 AM	23.2	165	WS720	3XP E71T1-H8	200146063	BASIC	B
352	1		100°C	107°C		7:20 AM	24.2	163	WS720	3XP E71T1-H8	200146063		
352	G	COPS-062	100°C	103°C		8:10 AM	23.2	163	WS720	3XP E71T1-H8	200146063		
352			100°C	106°C		9:10 AM	23.2	163	WS720	3XP E71T1-H8	200146063		
352			100°C	107°C		10:10 AM	24.5	220	WS720	3XP E71T1-H8	200146063		
352	2		100°C	106°C		11:00 AM	24.5	220	WS720	3XP E71T1-H8	200146063		
352	G	WPS-069	100°C	103°C		12:00 PM	24.5	220	WS720	3XP E71T1-H8	200146063		
352			100°C	107°C		1:00 PM	23.2	165	WS720	3XP E71T1-H8	200146063		
352	G		100°C	107°C		2:00 PM	23.2	165	WS720	3XP E71T1-H8	200146063		
352			100°C	108°C		3:00 PM	23.2	165	WS720	3XP E71T1-H8	200146063		
352			100°C	105°C		4:00 PM	23.2	165	WS720	3XP E71T1-H8	200146063		
										3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

### PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

*Kaw*

*G*

Client:	Minespec	Job No:	27861	Date:		Weld Procedure:	WPS-062, 064, 068
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish			

Job Description:	Refurbish Minespec 5600 Boom	Drawing No:	
------------------	------------------------------	-------------	--

Welder ID	Joint Type/ID	Weld Procedure No	Recommended Preheat Temp °c	Actual Preheat Temp °c	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
2.64			100°C	100°C	15-11-25	7AM	24	190	376	3XP E71T1-H8			
<i>1F</i> <i>2F</i> <i>3F</i>	<i>1F</i> <i>2F</i> <i>3F</i>	WPS-062		105°C		8AM	24	190	376	3XP E71T1-H8		<i>Bimal</i> <i>Basil</i>	
				110°C		9AM	24	190	376	3XP E71T1-H8			
				103°C		10AM	24	190	376	3XP E71T1-H8			
				111°C		11AM	24	190	376	3XP E71T1-H8			
				107°C		12pm	24	190	376	3XP E71T1-H8			
				104°C		1pm	24	190	376	3XP E71T1-H8			
				112°C		2pm	24	190	376	3XP E71T1-H8			
				103°C		3pm	24	190	376	3XP E71T1-H8			
				100°C		4pm	24	190	376	3XP E71T1-H8			
				115°C		5pm	24	190	376	3XP E71T1-H8			
			107°C		6pm	24	190	376	3XP E71T1-H8				

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm<	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

## WELDING & PRE-HEAT RECORD SHEET

Client:	Minespec	Job No:	27861	Date:	15.12.23	Weld Procedure:	WPS -062, 069, 068
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish			

Job Description:		Refurbish Minespec 5600 Boom					Drawing No:						
Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
214			100°C	105°C	15.12.23	6:30	26	200		3XP E71T1-H8			
				110°C		7:30	26	220		3XP E71T1-H8	20015/083		
	1F			115°C		8:30				3XP E71T1-H8			
		WPS -062		110°C		9:30				3XP E71T1-H8		Bimal	
	2F			112°C		10:30				3XP E71T1-H8		Basil	B
				117°C		11:30				3XP E71T1-H8			
				115°C		12:30				3XP E71T1-H8			
				118°C		1:30				3XP E71T1-H8			
		WPS -068		112°C		2:30				3XP E71T1-H8			
	3F			110°C		3:30				3XP E71T1-H8			
214				109°C		4:30				3XP E71T1-H8	20015/083		
										3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

### PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8



Mining Services

## WELDING & PRE-HEAT RECORD SHEET

Client: **Glencore Collinsville** Job No: **27861** Date: **3.12.24** Weld Procedure: **WPS-062, 064, 068**

Scope# Description: **Crack repair on 5600 Boom** Weld Size & Finish

Job Description: **Refrubish Minespec 5600 Boom** Drawing No:

Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
CA137	Fillet		100°	107	3.12.24	6:30	240	V	17A	E71T-12M H4 - Verticor 3XP	2001409030	BIMAL	B
			100°	112		7:30		V	A	E71T-12M H4 - Verticor 3XP			
			100°	115		8:30		V	A	E71T-12M H4 - Verticor 3XP			
		WPS-062	100°	110		9:30		V	A	E71T-12M H4 - Verticor 3XP			
			100°	113		10:30		V	A	E71T-12M H4 - Verticor 3XP			
			100°	116		11:30		V	A	E71T-12M H4 - Verticor 3XP			
		WPS-068	100°	114		12:30		V	A	E71T-12M H4 - Verticor 3XP			
			100°	117		13:30		V	A	E71T-12M H4 - Verticor 3XP			
			100°	110		14:30		V	A	E71T-12M H4 - Verticor 3XP			
			100°	113		15:30		V	A	E71T-12M H4 - Verticor 3XP			
			100°	111		16:30		V	A	E71T-12M H4 - Verticor 3XP			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

### PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8

Caleb.



WELDING & PRE-HEAT RECORD SHEET

Client:	Minespec	Job No:	27861	Date:		Weld Procedure:	WPS-062, 064, 068						
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish									
Job Description:	Refurbish Minespec 5600 Boom			Drawing No:									
Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °c	Actual Preheat Temp °c	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
Q-364			120	130	17-1-21	7Am	23	180	377	3XP E71T1-H8			
364			120	130	17-1-21	8Am	23	180	377	3XP E71T1-H8			
364	1F		120	130	17-1-21	9Am	23	180	377	3XP E71T1-H8			
364		WPS-062	120	136		10Am	23	180	377	3XP E71T1-H8			
364	2F		120	133		11Am	23	180	377	3XP E71T1-H8			
364			120	131		12pm	23	180	377	3XP E71T1-H8		BIMAC	B
364			120	132		1pm	23	180	377	3XP E71T1-H8		BASIL	
364	3F	WPS-068	120	134		2pm	23	180	377	3XP E71T1-H8			
364			120	135		3pm	23	180	377	3XP E71T1-H8			
364			120	133		4pm	23	180	377	3XP E71T1-H8			
										3XP E71T1-H8			
										3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

**WELDING & PRE-HEAT RECORD SHEET**

Client:	Minespec	Job No:	27861	Date:	24-1-24	Weld Procedure:	WPS-062, 064, 068						
Scope#		Description:	Crack repair on 5600 Boom	Weld Size & Finish									
Job Description:	Refurbish Minespec 5600 Boom			Drawing No:									
Welder ID	Joint Type/ID	Weld Procedure No	Recommended Preheat Temp °c	Actual Preheat Temp °c	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
364			120	130 6 AM	24-1	6 AM	23	180	379	3XP E71T1-H8			
364	1F		120	130 7 AM	24-1	7 AM	23	180	379	3XP E71T1-H8			
364			120	132	24-1	8 AM	23	180	379	3XP E71T1-H8			
364		WPS-062	120	136	24-1	9 AM	23	180	379	3XP E71T1-H8			
364	2F		120	130	24-1	10 AM	23	180	379	3XP E71T1-H8			
364			120	130	24-1	11 AM	23	180	379	3XP E71T1-H8			
364			120	134	24-1	12 PM	23	180	379	3XP E71T1-H8			
364	3F	WPS-068	120	133	24-1	1 PM	23	180	379	3XP E71T1-H8			
364			120	138	24-1	2 PM	23	180	379	3XP E71T1-H8			
										3XP E71T1-H8			
										3XP E71T1-H8			
										3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

## WELDING & PRE-HEAT RECORD SHEET

Client:	Mine spec	Job No:	27861	Date:	6/2/24	Weld Procedure	WPS-002,032						
Scope #	Description	closing of windows				weld Size & Finish							
Job Description:		Refurbish Minespec 5600 Boom				Drawing No:							
Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
00324	Butt Joint		75°C	77°C	6/2/24	6 AM	25.0 V	260 A	WS375	3XP E71T1-H8	3XP 16mm 3XP With Cap	2015/108B	Binal Raul B
				79°C		7 AM	V	A		3XP E71T1-H8			
				82°C		8 AM	V	A		3XP E71T1-H8			
				85°C		9 AM	V	A		3XP E71T1-H8			
				87°C		10 AM	V	A		3XP E71T1-H8			
				76°C		11 AM	V	A		3XP E71T1-H8			
				77°C		12 PM	V	A		3XP E71T1-H8			
				79°C		1 PM	V	A		3XP E71T1-H8			
				81°C		2 PM	V	A		3XP E71T1-H8			
				78°C		3 PM	V	A		3XP E71T1-H8			
				79°C		4:58 PM	V	A		3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

### PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

## WELDING & PRE-HEAT RECORD SHEET

Client:	Mine spec	Job No:	27861	Date:	7/2/24	Weld Procedure	WPS-002,032
---------	-----------	---------	-------	-------	--------	----------------	-------------

Scope #	Description	closing of windows		weld Size & Finish
---------	-------------	--------------------	--	--------------------

Job Description:	Refurbish Minespec 5600 Boom	Drawing No:
------------------	------------------------------	-------------

Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
CS24	Burr Joint		75°	78°	7/2/24	6 AM	25.0 V	26° A	WS375	3XP E71T1-H8			
				80°		7 AM	V	A		3XP E71T1-H8			
				82°		8 AM	V	A		3XP E71T1-H8			
				83°		9 AM	V	A		3XP E71T1-H8			
				85°		10 AM	V	A		3XP E71T1-H8			
				76°		11 AM	V	A		3XP E71T1-H8			
				77°		12 PM	V	A		3XP E71T1-H8			
				79°		1 PM	V	A		3XP E71T1-H8			
				80°		2 PM	V	A		3XP E71T1-H8			
				78°		3 PM	V	A		3XP E71T1-H8			
				80°		4:50 PM	V	A		3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

### PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm<	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

**WELDING & PRE-HEAT RECORD SHEET**

Client:	Mine spec	Job No:	27861	Date:	8/2/24	Weld Procedure							
Scope #		Description	closing of windows	weld Size & Finish									
Job Description: Refurbish Minespec 5600 Boom				Drawing No:									
Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
CA324	BUTT JOINT		75°	76°	8/2/24	6 AM	250 V	250 A	WS375	VIRTI CORP 3XP 16mm	2001511083	Bimal	[Signature]
				78°		7 AM	V	A					
				80°	8/2/24	8 AM	V	A					
				83°		9 AM	V	A					
				85°		10 AM	V	A					
				78°		11 AM	V	A					
				81°		12 PM	V	A					
				83°		1 PM	V	A					
				86°		2 PM	V	A					
				79°		3 PM	V	A					
				83°		4:50 PM	V	A					

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

**PRE-HEAT and CONSUMABLE GUIDE**

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8



## WELDING & PRE-HEAT RECORD SHEET

Client:	Mine spec	Job No: 27861	Date:	Weld Procedure	WPS-002,032
---------	-----------	---------------	-------	----------------	-------------

Scope #	Description	closing of windows	weld Size & Finish
---------	-------------	--------------------	--------------------

Job Description:	Refurbish Minespec 5600 Boom	Drawing No:
------------------	------------------------------	-------------

Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
CQ-337	BUTT JOINT		75°C	76°C	9/2/24	6am	250	250	A	3XP E71T1-H8		Blanc Basel	B
				78°C		7am			A	3XP E71T1-H8			
				80°C		8am			A	3XP E71T1-H8			
				83°C		9am			A	3XP E71T1-H8			
				85°C		10am			A	3XP E71T1-H8			
				78°C		11am			A	3XP E71T1-H8			
				81°C		12am			A	3XP E71T1-H8			
				83°C		1pm			A	3XP E71T1-H8			
				86°C		2pm			A	3XP E71T1-H8			
				79°C		3pm			A	3XP E71T1-H8			
				83°C		4:50pm			A	3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

### PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm<	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

Uncontrolled If Printed



Mining Services

## WELDING & PRE-HEAT RECORD SHEET

Client:	Mine spec	Job No:	27861			Date:				Weld Procedure	WPS -002,032		
Scope #	Description					closing of windows		weld Size & Finish					
Job Description:		Refurbish Minespec 5600 Boom					Drawing No:						
Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
CQ-337	BURT JOINT		75°C	76°C	10/2/24	6 am	250	V	A		3XP E71T1-H8	BIMAC	B
				78°C		7 am		V			3XP E71T1-H8		
				80°C		8 am		V			3XP E71T1-H8		
				83°C		9 am		V			3XP E71T1-H8		
				85°C		10 am		V			3XP E71T1-H8		
				78°C		11 am		V			3XP E71T1-H8		
				81°C		12 am		V			3XP E71T1-H8		
				82°C		1 pm		V			3XP E71T1-H8		
				86°C		2 pm		V			3XP E71T1-H8		
				79°C		3 pm		V			3XP E71T1-H8		
				82°C		4:50 pm		V			3XP E71T1-H8		

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

### PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm<	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

Uncontrolled If Printed



Mining Services

## WELDING & PRE-HEAT RECORD SHEET

Client:	Mine spec	Job No:	27861		Date:				Weld Procedure	WPS -002,032				
Scope #		Description	closing of windows			weld Size & Finish								
Job Description:		Refurbish Minespec 5600 Boom				Drawing No:								
Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials	
CQ-290	BUTT JOINT		75°C.	76°C	11/2/24	6am	250	V	A	3XP E71T1-H8		Bimal	B	
				77°C		7am		V			A			3XP E71T1-H8
				80°C		8am		V			A			3XP E71T1-H8
				83°C		9am		V			A			3XP E71T1-H8
				85°C		10am		V			A			3XP E71T1-H8
				78°C		11am		V			A			3XP E71T1-H8
				81°C		12am		V			A			3XP E71T1-H8
				83°C		1pm		V			A			3XP E71T1-H8
				86°C		2pm		V			A			3XP E71T1-H8
				79°C.		3pm		V			A			3XP E71T1-H8
				83°C.		4:50pm.		V			A			3XP E71T1-H8

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

### PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm<	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

Uncontrolled If Printed

## WELDING & PRE-HEAT RECORD SHEET

Client:	Mine spec	Job No:	27861	Date:		Weld Procedure	WPS-002,032							
Scope #		Description	closing of windows		weld Size & Finish									
Job Description:		Refurbish Minespec 5600 Boom			Drawing No:									
Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °c	Actual Preheat Temp °c	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials	
CQ-240	BUTT JOINT		75°C	76°C	12/2/24	6am	250 V	250 A		3XP E71T1-H8			BASIC	
				74°C			7am	V	A		3XP E71T1-H8			
				80°C			8am	V	A		3XP E71T1-H8			
				83°C			9am	V	A		3XP E71T1-H8			
				85°C			10am	V	A		3XP E71T1-H8			
				78°C			11am	V	A		3XP E71T1-H8			
				81°C			12am	V	A		3XP E71T1-H8			
				83°C			1:00pm	V	A		3XP E71T1-H8			
				86°C			2:00pm	V	A		3XP E71T1-H8			
				79°C			3:00pm	V	A		3XP E71T1-H8			
				83°C			4:50pm	V	A		3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

### PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm<	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8



Mining Services

## WELDING & PRE-HEAT RECORD SHEET

Client:	Glencore Collinsville		Job No:	27861	Date:	21-24	Weld Procedure:	COPS - 062, 064, 068	
Scope#		Description:	Crack repair on 5600 Boom			Weld Size & Finish			

Job Description:	Refrubish Minespec 5600 Boom	Drawing No:	
------------------	------------------------------	-------------	--

Welder ID	Joint Type/ ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
CQ137	Fillet		100°	110	21-24	6:30	240	V	177A	E71T-12M H4 - Verticor 3XP	2001409036	BIMAL BASIC	Ba
↓	↓		100°	115		7:30		V	A	E71T-12M H4 - Verticor 3XP			
↓	↓	COPS-062	100°	105		8:30		V	A	E71T-12M H4 - Verticor 3XP			
↓	↓		100°	107		9:30		V	A	E71T-12M H4 - Verticor 3XP			
↓	↓		100°	113		10:30		V	A	E71T-12M H4 - Verticor 3XP			
↓	↓	COPS-068	100°	111		11:30		V	A	E71T-12M H4 - Verticor 3XP			
↓	↓		100°	116		12:30		V	A	E71T-12M H4 - Verticor 3XP			
↓	↓		100°	110		13:30		V	A	E71T-12M H4 - Verticor 3XP			
↓	↓		100°	122		14:30		V	A	E71T-12M H4 - Verticor 3XP			
↓	↓		100°	114		15:30		V	A	E71T-12M H4 - Verticor 3XP			
↓	↓		100°	116		16:30		V	A	E71T-12M H4 - Verticor 3XP			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

### PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm<	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8

**WELDING & PRE-HEAT RECORD SHEET**

Client:	Minespec	Job No:	27861	Date:	4.1.24	Weld Procedure:	WPS-062, 064.						
Scope#	Description:	Crack repair on 5600 Boom		Weld Size & Finish									
Job Description:	Refurbish Minespec 5600 Boom			Drawing No:	BAT #4								
Welder ID	Joint Type/ID	Weld Procedure No	Recommended Preheat Temp °C	Actual Preheat Temp °C	Date Taken	Time Taken	Volts	Amps	Plant ID	Consumable Used	Consumable Batch No:	Inspected By: Print Name	Inspected By: Initials
CR137	tail		100c	110c	4/24	6:30	24.3	177	W18	3XP E71T1-H8	200151083	BIMAL BASIL	B
				113c		7:30				3XP E71T1-H8			
				115c		8:30				3XP E71T1-H8			
	1F	WPS-062		117		9:30				3XP E71T1-H8			
				120		10:30				3XP E71T1-H8			
	2F			119		11:30				3XP E71T1-H8			
		WPS-064		107		12:30				3XP E71T1-H8			
				108		13:30				3XP E71T1-H8			
	4F			115		14:30				3XP E71T1-H8			
				116		15:30				3XP E71T1-H8			
				119		16:30				3XP E71T1-H8			
			100c	118		17:30				3XP E71T1-H8			

\* NOTE: Readings to be recorded first when the recommended temperature is reached & once every Hour during Welding.

PRE-HEAT and CONSUMABLE GUIDE

Material	20mm & Under	20mm - 40mm	40mm - 60mm	60mm <	Process	Consumable
Q & T 80	100°C	100°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 400	150°C	150°C	150°C	200°C	FCAW	E81T1-N1-H4
Q & T 450	150°C	150°C	150°C	150°C	FCAW	E81T1-N1-H4
GR250	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
GR350	75°C	75°C	75°C	108°C	FCAW/GMAW	E71T1-H8
Cruesabro	30°C	30°C	30°C	30°C	FCAW	E71T1-H8

*Handwritten signature/initials*

*Section 6*

# MACHINING

Document Name	Document ID	Version	Issue Date	Page
Workshop MDR	F_QA-013	1	10.02.2019	Page 8 of 9



Josho's Lineboring  
 Mick Walker  
 0438080005  
 jp@joshos.com.au  
 26 Len Shield Street, Paget QLD 4740  
 ABN: 93 146 329 982

## Quality Assurance Form

<b>Customer</b>	CQFMS
<b>Location</b>	Mackay
<b>Job Number</b>	J27861
<b>Date</b>	14/12/2023
<b>Plant No</b>	EX5500 Boom
<b>Job Description</b>	Bore report before Machining

Bore	Specified Size	Bore Position	Actual Size
1.	300.00+0.05/-0.00	Boom to House LH	300.20 (0.15mm Oversize)
2.	300.00+0.05/-0.00	Boom to House RH	300.35 (0.30mm Oversize)
3.	320.00+0.05/-0.00	Boom to Stick LH	320.80 (0.75mm Oversize)
4.	320.00+0.05/-0.00	Boom to Stick RH	321.10 (1.05mm Oversize)
5.	230.00+0.10/-0.00	Boom Lift Cyl LH Outer	230.45 (0.35mm Oversize)
6.	230.00+0.10/-0.00	Boom Lift Cyl LH Inner	230.55 (0.45mm Oversize)
7.	230.00+0.10/-0.00	Boom Lift Cyl RH Outer	230.60 (0.50mm Oversize)
8.	230.00+0.10/-0.00	Boom Lift Cyl RH Inner	230.65 (0.55mm Oversize)
9.	260.00+0.10/-0.00	Boom to Stick Cyl LH Outer	260.80 (0.70mm Oversize)
10.	260.00+0.10/-0.00	Boom to Stick Cyl LH Inner	260.60 (0.50mm Oversize)
11.	260.00+0.10/-0.00	Boom to Stick Cyl RH Outer	260.85 (0.75mm Oversize)
12.	260.00+0.10/-0.00	Boom to Stick Cyl RH Inner	260.65 (0.55mm Oversize)
13.	<b>FACES:</b>		
14.		<b>Boom To Super Structure</b>	
15.	410.00+/-0.50mm	LH Ear Width	410.00
16.	1770.00	Inside to Inside	1770.00
17.	410.00+/-0.50mm	RH Ear Width	410.00
18.	2590.00+/-1mm	Outside to Outside	2589.00
19.		<b>Boom to Stick Faces</b>	
20.	440.00+/-1.00	Boom To Stick LH	438 (1mm undersize)
21.	440.00+/-1.00	Boom To Stick RH	438 (1mm undersize)
22.	1540.00+/-1.00	Outside to Outside	1536 (3mm Undersize)
23.	660.00+/-1.00	Inside to Inside	660.00




Josho's Lineboring  
**Mick Walker**  
0438080005  
jp@joshos.com.au  
26 Len Shield Street, Paget QLD 4740  
ABN: 93 146 329 982

Notes: All bores are oversize up to 1.05mm. Faces on the boom to stick end are oversize and are scratched up. Faces on the boom to house bores are on size however are scratched up as well. Up to the client if they would like it to be welded and machined or just welded and blended back.

Large cracks around cylinder mount bores as well as each end of the boom. Therefore, after crack repairs have been completed Lineboring will be required to ensure alignment of the pins.

Photos attached.





Josho's Lineboring  
Mick Walker  
0438080005  
jp@joshos.com.au  
26 Len Shield Street, Paget QLD 4740  
ABN: 93 146 329 982





Josho's Lineboring  
Mick Walker  
0438080005  
jp@joshos.com.au  
26 Len Shield Street, Paget QLD 4740  
ABN: 93 146 329 982






Josho's Lineboring  
Mick Walker  
0438080005  
jp@joshos.com.au  
26 Len Shield Street, Paget QLD 4740  
ABN: 93 146 329 982





Josho's Lineboring  
**Mick Walker**  
0438080005  
jp@joshos.com.au  
26 Len Shield Street, Paget QLD 4740  
ABN: 93 146 329 982

---



## Quality Assurance Form

Start Date: 13/02/2024


Finish Date: 15/02/2024

Customer/Location: CQ Workshop

Job Number: 29025

Plant Number: Minespec – Hitachi 5600 Boom


Job Description: Boom to Superstructure and Boom to Stick Bores



Condition	A		B		Standard Inner Dia. (mm)
	X-X	Y-Y	X-X	Y-Y	
<input type="checkbox"/> Pre-machining <input checked="" type="checkbox"/> Post-machining					
<b>Bore 1</b>	320.00	320.00	320.00	320.00	000 <sup>+0.0</sup> <sub>-0.0</sub>
<b>Bore 2</b>	320.00	320.00	320.00	320.00	
<b>Bore 3</b>					000 <sup>+0.0</sup> <sub>-0.0</sub>
<b>Bore 4</b>					
<b>Bore 5</b>					000 <sup>+0.0</sup> <sub>-0.0</sub>
<b>Bore 6</b>					
<b>Bore 7</b>	300.04	300.04	300.06	300.06	000 <sup>+0.0</sup> <sub>-0.0</sub>
<b>Bore 8</b>	300.02	300.02	300.03	300.03	

<b>Client Direction:</b>	<input type="checkbox"/> No Machining Required <input type="checkbox"/> Reclaim Bores
--------------------------	--

## Quality Assurance Form



Note:

- 1) All bush arrangements are similar at each location.
- 2) Refer to above Boom figure for bush locations.

Bushing	Condition (New/ Used)	A (Inner Dia.)		B (Outer Dia.)		C (Inner Dia.)		D (Outer Dia.)		Standard (mm)
		X-X	Y-Y	X-X	Y-Y	X-X	Y-Y	X-X	Y-Y	
Bushing 1	Old/ <b>New</b>			320.55	320.55			320.55	320.55	Inner Dia. 280 <sup>+0.70</sup> <sub>+0.60</sub>
Bushing 2	Old/ <b>New</b>			320.55	320.55			320.55	320.55	Outer Dia. 320 <sup>+0.60</sup> <sub>+0.55</sub>
Bushing 7	Old/ <b>New</b>			300.50	300.50			300.51	300.51	Inner Dia. 260 <sup>+0.65</sup> <sub>+0.55</sub>
Bushing 8	Old/ <b>New</b>			300.50	300.51			300.51	300.50	Outer Dia. 300 <sup>+0.55</sup> <sub>+0.50</sub>

<b>Machine ID:</b> Mine spec Hitachi 5600 Boom	<b>Measured by:</b> Brett Steele	<b>Date:</b> 15/02/24	<b>Client Direction:</b> <input type="checkbox"/> Reuse Old Parts <input checked="" type="checkbox"/> Fit New Parts
<b>FMS Rep Name:</b>  X  Leigh Currell Machining Coordinator			
<b>Client Rep Name:</b>	<b>Client Rep Approval Signature:</b>		

Notes: No Photos recorded.

*Section 7*

# MATERIAL CERTIFICATES

Document Name	Document ID	Version	Issue Date	Page
Workshop MDR	F_QA-013	1	10.02.2019	Page 9 of 9

**TEST CERTIFICATE**

Customer: <b>COIL STEELS PTY LTD PO BOX 1594 BROWNS PLAINS BC Q L D 4118</b>	Supplier: <b>BLUESCOPE STEEL (AIS) PTY LTD PORT KEMBLA, N.S.W., AUSTRALIA. A.B.N. 19 000 019 625</b>
Cust Order No: 24428	Sales Order No: B1146 Printed At: Supplier MWS on: 20/04/2022



Accredited for compliance with ISO/IEC 17025 - Testing.

I certify that the original records of the company show that the item(s) referred to on this certificate conform to the specification as stated.

R.MATHIESSEN - BLUESCOPE STEEL APPROVED SIGNATORY  
Mechanical LAB 0631  
M.GATRICK - BLUESCOPE STEEL APPROVED SIGNATORY  
Chemical LAB 0632

STEELMAKING: Basic Oxygen - Slab Cast  
SPECIFICATION: **AS/NZS 3678-350**  
PRODUCT: **XLERPLATE**

INSPECTION: Supplier  
CERTIFICATION: EN10204 3.1

**CHEMICAL ANALYSIS**

Percentage of element by mass (L=Cast, P=Product, -S=Soluble, -T=Total, CF=Chemical Formula, n=Min, x=Max)

Item No	Heat / Unit No	NATA Lab	L/P	C	P	Mn	Si	S	Ni	Cr	Mo	Cu	Al-T
0538	7810199	0632	L	.156	.023	1.23	.31	.011	.017	.046	.003	.044	.024
0539	7810198	0632	L	.156	.023	1.23	.31	.011	.017	.046	.003	.044	.024
0539	7810199	0632	L	.156	.023	1.23	.31	.011	.017	.046	.003	.044	.024

Item No	Heat / Unit No	NATA Lab	L/P	Ti	B-T	Nb	V	CF1	CF2	CF3
0538	7810199	0632	L	.019	.0003	.001	<.003	.37	.11	.02
0539	7810198	0632	L	.019	.0003	.001	<.003	.37	.11	.02
0539	7810199	0632	L	.019	.0003	.001	<.003	.37	.11	.02

$$CF1=C+(MN/6) + ((CR+MO+V)/5) + ((CU+NI)/15) \quad CF2=NI + CR + CU + MO \quad CF3=NB + TI + V$$
**MECHANICAL TESTING****Tensile AS 1391 :2020 B**

Item No	Heat No	Tested Unit	NATA Lab	Cat	Loc	THICK mm	ReH MPa	Rm MPa	Lo	ELONGN %
0539	7810198	WN008	0631	B	TQM	10.00	395	520	A	38
0539	7810199	WM980	0631	B	TQM	10.00	395	520	A	35
0538	7810199	WN047	0631	P	TQM	12.00	385	520	A	34

**ITEMS COVERED BY THIS CERTIFICATE**

Item No	Heat No	Ordered Dimensions (mm)	No of Units	Mass (Tonnes)	Unit Identities
0538	7810199	2400.0X12.00X6000	5	6.780	WN047A1 WN047A2 WN047A3 WN047B1 WN047B2
0539	7810198	2400.0X10.00X6000	18	20.340	WN006A1 WN006A2 WN006A3 WN006B1 WN006B2 WN006B3 WN007A1 WN007A2 WN007A3 WN007B1 WN007B2 WN007B3 WN008A1 WN008A2 WN008A3 WN008B1 WN008B2 WN008B3
0539	7810199	2400.0X10.00X6000	21	23.730	WN002B1 WN002B2 WN002B3 WN003A1 WN003A2 WN003A3 WN003B1 WN003B2 WN003B3 WN004A1 WN004A2 WN004A3 WN004B1 WN004B2 WN004B3 WN009A1 WN009A2 WN009A3 WN009B1 WN009B2 WN009B3

**COMMENTS**

This test certificate is issued subject to the Uncertainty of Results statement set out on BlueScope Steel's Website

[www.bluescopesteelconnect.com](http://www.bluescopesteelconnect.com). In order to rely upon this certificate, you must read the Uncertainty of Results statement.

THIS PRODUCT IS SUPPLIED IN ACCORDANCE WITH THE REQUIREMENTS OF AS/NZS 3678:2016. SAMPLING AND CHEMICAL ANALYSIS ARE PERFORMED IN ACCORDANCE WITH BLUESCOPE STEEL PROCEDURE DH-LABS-QS-00 S05.07C. MECHANICAL TESTING HAS BEEN PERFORMED ON SAMPLES SUPPLIED BY THE RELEVANT PRODUCTION DEPARTMENTS. HEAT TREATMENT - PRODUCT AS ROLLED.

Quality management system conforms to AS/NZS ISO 9001 as assessed by BSI (Certificate Number FS 594448).

---


**MECHANICAL COMMENTS**

TEST PIECE LOCATION (LOC) TQM=Transverse Quarter Middle

TEST CATEGORY (CAT) P=Pattern B=Batch

GAUGE LENGTH (Lo)  $A=5.65 \times \text{square root of the original cross-sectional area of the test piece.}$

---



BlueScope



This testing laboratory is accredited in accordance with the recognized international Standard ISO/IEC 17025:2005

# TEST CERTIFICATE



당진제철소 : 충남 당진시 송악읍 북부산로 1480  
1480 Bukbusenup-Ro, Songak-Eup, Dangjin-Si, Chungnam, Korea



주문번호 Order No.	: E230300572	고객사 Customer	: CRONOS	증명서 번호 Certificate No.	: 20230603-PS-0014-005
품명 Commodity	: Hot Rolled Steel Plate	주문자 Contractor	: DITH AUSTRALIA PTY LTD	발행일자 Date of Issue	: 2023-06-03
제품규격 Specification	: AS/NZS 3678-350L0				

제품치수 Dimension	수량 Quantity	중량 Weight (Kg)	제강번호 Heat No.	제품번호 Product No.	Position	인장시험 Tensile Test						충격시험 Impact Test V Notch +0.0 °C			화학성분 Chemical Composition(%)													단위 Unit 2 : x 100    3 : x 1,000 4 : x 10,000    5 : x 100,000				
						YP	TS	EL	YP-EL	RA	YR	YP Mtd	Energy	SF	LE	Division	C	Si	Mn	P	S	Cr	Ni	B	Cu	Mo	Nb	Ti	V	Sol-Al	CEQ	CA
						(N/mm <sup>2</sup> ) ( )	(%)	(%)	(%)	(%)	(%)	(mm)	(Joule)	(%)	(mm)		4	3	3	4	4	2	2	4	3	2	3	3	3	3	3	3
10.00x2000x4000	1	628	S66626	FD09463302	T	450.6	577.4	31				U	1:176 2:193 3:166 A:178			L	1,524	353	1,457	104	47	2	2	4	23	0	19	2	3	37	403	24
10.00x2000x4000	1	628	S66626	FD09463303	T	450.6	577.4	31				U	1:176 2:193 3:166 A:178			L	1,524	353	1,457	104	47	2	2	4	23	0	19	2	3	37	403	24
10.00x2000x4000	1	628	S66626	FD09463304	T	450.6	577.4	31				U	1:176 2:193 3:166 A:178			L	1,524	353	1,457	104	47	2	2	4	23	0	19	2	3	37	403	24
10.00x2000x4000	1	628	S66626	FD09463305	T	450.6	577.4	31				U	1:176 2:193 3:166 A:178			L	1,524	353	1,457	104	47	2	2	4	23	0	19	2	3	37	403	24

**N O T E**

\* Position - T:Top, M:Middle, B:Bottom  
 \* Tensile test - Direction:Transverse, Gauge length:200mm (Rectangular), Elongation is converted to elongation on gauge length 5.65√A. by ISO 2566-1, YP Mtd : 2 (0.2% off-set), 5 (0.5% underload), U (Upper yield point), L (Lower yield point)  
 \* Impact test - Direction:Longitudinal, Sub-size:10mmX7.5mm, SF:Shear fracture, LE:Lateral Expansion  
 \* Division - P:Product analysis, L:Ladle analysis

\* THIS CERTIFICATE IS ISSUED ACCORDING TO EN 10204 3.1 / 7503010074  
 \* The plate is fully killed steel. Basic oxygen process and Vacuum degassing process were applied. \* Test Method : 1) Chemical Composition (ASTM E415), 2) Tensile Test (AS 1391), 3) Impact Test (AS 1544.2) \* ISO 9001 is certified by BSI (Cert. no. FM701483) \* KOLAS CERTIFIED LAB. NO. KT533\* This Mill Test Certificate is issued in accordance with EN 10204 Type 3.1

상기의 제품은 검사의 결과 지정된 규격에 합격한 것을 증명합니다.  
 WE HEREBY CERTIFY THAT THE MATERIAL HAS BEEN MADE AND TESTED IN ACCORDANCE WITH THE ABOVE SPECIFICATION AND THE REQUIREMENTS

Signature *Kim in*  
 Chief Of Plate Quality Team

\* 본 검사증명서는 원본인 전자문서(전자서명 정보 포함)로부터 출력된 사본입니다. 전자문서의 내용은 현대제철 고객포탈에서 확인하실 수 있습니다.(http://sm.hyundai-steel.com/cs/cm/login.jsp)  
 \* This Mill Test Certificate is a copy that has been printed from original electronic document(with digital signing).  
 You are able to check an original electronic document at hyundai-steel's customer portal.( http://sm.hyundai-steel.com/cs/cm/login.jsp) \* QRcode scanner App : 'QReal'  
 \* [사용상 주의사항] 본 검사증명서에 명기된 규격 외 사용시 제품손상 및 안전상 문제가 발생할 수 있습니다.  
 \* [Caution for Use] Damage on products and safety problems may arise if used other than to the spec stated in this Mill Test Certification.

**TEST CERTIFICATE**

Customer: <b>COIL STEELS PTY LTD PO BOX 1594 BROWNS PLAINS BC Q L D 4118</b>	Supplier: <b>BLUESCOPE STEEL (AIS) PTY LTD PORT KEMBLA, N.S.W., AUSTRALIA. A.B.N. 19 000 019 625</b>
Cust Order No: 27922	Sales Order No: B3146 Printed At: Supplier MWS on: 23/11/2023

<p>Accredited for compliance with ISO/IEC 17025 - Testing.</p>	I certify that the original records of the company show that the item(s) referred to on this certificate conform to the specification as stated.
	<p>I.ZAFAR - BLUESCOPE STEEL APPROVED SIGNATORY Mechanical LAB 0631 M.GATRICK - BLUESCOPE STEEL APPROVED SIGNATORY Chemical LAB 0632</p>

STEELMAKING: Basic Oxygen - Slab Cast  
SPECIFICATION: **AS/NZS 3678-350**  
PRODUCT: **XLERPLATE**

INSPECTION: Supplier  
CERTIFICATION: EN10204 3.1

**CHEMICAL ANALYSIS**

Percentage of element by mass (L=Cast, P=Product, -S=Soluble, -T=Total, CF=Chemical Formula, n=Min, x=Max)

Item No	Heat / Unit No	NATA Lab	L/P	C	P	Mn	Si	S	Ni	Cr	Mo	Cu	Al-T
1385	7913628	0632	L	.087	.023	1.41	.38	.015	.018	.047	.003	.054	.042

Item No	Heat / Unit No	NATA Lab	L/P	Ti	B-T	Nb	V	CF1	CF2	CF3
1385	7913628	0632	L	.018	.0004	.026	<.003	.34	.12	.04

CF1=C+ (MN/6) + ((CR+MO+V)/5) + ((CU+NI)/15) CF2=NI + CR + CU + MO CF3=NB + TI + V

**MECHANICAL TESTING****Tensile AS 1391 :2020 B**

Item No	Heat No	Tested Unit	NATA Lab	Cat	Loc	THICK mm	ReH MPa	Rm MPa	Lo	ELONGN %
1385	7913628	DF979	0631	B	TQF	32.00	445	520	A	27
1385	7913628	DF982	0631	B	TQF	32.00	420	510	A	30

**ITEMS COVERED BY THIS CERTIFICATE**

Item No	Heat No	Ordered Dimensions (mm)	No of Units	Mass (Tonnes)	Unit Identities
1385	7913628	2400.0X32.00X8300	2	10.008	<b>DK483A1 DK484A1</b>

**COMMENTS**

This test certificate is issued subject to the Uncertainty of Results statement set out on BlueScope Steel's Website

[www.bluescopesteelconnect.com](http://www.bluescopesteelconnect.com). In order to rely upon this certificate, you must read the Uncertainty of Results statement.

THIS PRODUCT IS SUPPLIED IN ACCORDANCE WITH THE REQUIREMENTS OF AS/NZS 3678:2016. SAMPLING AND CHEMICAL ANALYSIS ARE PERFORMED IN ACCORDANCE WITH BLUESCOPE STEEL PROCEDURE DH-LABS-QS-00 S05.07C. MECHANICAL TESTING HAS BEEN PERFORMED ON SAMPLES SUPPLIED BY THE RELEVANT PRODUCTION DEPARTMENTS. HEAT TREATMENT - PRODUCT AS ROLLED. Quality management system conforms to AS/NZS ISO 9001 as assessed by BSI (Certificate Number FS 594448).

**MECHANICAL COMMENTS**

TEST PIECE LOCATION (LOC) TQF=Transverse Quarter Front End

TEST CATEGORY (CAT) B=Batch

GAUGE LENGTH (Lo) A=5.65 \* square root of the original cross-sectional area of the test piece.

**TEST CERTIFICATE**

Customer: <b>INFRABUILD STEEL CENTRE NORTH MACKAY Q L D 4740</b>	Supplier: <b>BLUESCOPE STEEL (AIS) PTY LTD PORT KEMBLA, N.S.W., AUSTRALIA. A.B.N. 19 000 019 625</b>
Cust Order No: 7507359446	Sales Order No: F3574 Printed At: Supplier MWS on: 30/11/2023



Accredited for compliance with ISO/IEC 17025 - Testing.

I certify that the original records of the company show that the item(s) referred to on this certificate conform to the specification as stated.

I.ZAFAR - BLUESCOPE STEEL APPROVED SIGNATORY  
Mechanical LAB 0631M.GATRICK - BLUESCOPE STEEL APPROVED SIGNATORY  
Chemical LAB 0632

STEELMAKING: Basic Oxygen - Slab Cast

SPECIFICATION: **AS/NZS 3678-350**PRODUCT: **XLERPLATE**

INSPECTION: Supplier

CERTIFICATION: EN10204 3.1

**CHEMICAL ANALYSIS**

Percentage of element by mass (L=Cast, P=Product, -S=Soluble, -T=Total, CF=Chemical Formula, n=Min, x=Max)

Item No	Heat / Unit No	NATA Lab	L/P	C	P	Mn	Si	S	Ni	Cr	Mo	Cu	Al-T
0533	7915919	0632	L	.089	.016	1.50	.34	.014	.019	.024	.003	.061	.031

Item No	Heat / Unit No	NATA Lab	L/P	Ti	B-T	Nb	V	CF1	CF2	CF3
0533	7915919	0632	L	.017	.0005	.027	<.003	.35	.11	.04

CF1=C+ (MN/6) + ((CR+MO+V)/5) + ((CU+NI)/15) CF2=NI + CR + CU + MO CF3=NB + TI + V

**MECHANICAL TESTING****Tensile AS 1391 :2020 B**

Item No	Heat No	Tested Unit	NATA Lab	Cat	Loc	THICK mm	ReH MPa	Rm MPa	Lo	ELONGN %
0533	7915919	DK562	0631	B	TQF	50.00	400	510	A	30
0533	7915919	DK569	0631	B	TQF	50.00	380	500	A	31

**ITEMS COVERED BY THIS CERTIFICATE**

Item No	Heat No	Ordered Dimensions (mm)	No of Units	Mass (Tonnes)	Unit Identities
0533	7915919	2400.0X50.00X7600	1	7.159	<b>DK564A1</b>

**COMMENTS**

This test certificate is issued subject to the Uncertainty of Results statement set out on BlueScope Steel's Website

[www.bluescopesteelconnect.com](http://www.bluescopesteelconnect.com). In order to rely upon this certificate, you must read the Uncertainty of Results statement.

THIS PRODUCT IS SUPPLIED IN ACCORDANCE WITH THE REQUIREMENTS OF AS/NZS 3678:2016. SAMPLING AND CHEMICAL ANALYSIS ARE PERFORMED IN ACCORDANCE WITH BLUESCOPE STEEL PROCEDURE DH-LABS-QS-00 S05.07C. MECHANICAL TESTING HAS BEEN PERFORMED ON SAMPLES SUPPLIED BY THE RELEVANT PRODUCTION DEPARTMENTS. HEAT TREATMENT - PRODUCT AS ROLLED.

Quality management system conforms to AS/NZS ISO 9001 as assessed by BSI (Certificate Number FS 594448).

**MECHANICAL COMMENTS**

TEST PIECE LOCATION (LOC) TQF=Transverse Quarter Front End

TEST CATEGORY (CAT) B=Batch

GAUGE LENGTH (Lo) A=5.65 \* square root of the original cross-sectional area of the test piece.